MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 1222 Maple Dr.
Sampled: 06/08/12 at 05:01 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614934
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.154	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.003	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 632 WEBER DR
Sampled: 06/06/12 at 03:00 PM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614935
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.089	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	< 0.001	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 114 DAVID DR
Sampled: 06/11/12 at 05:50 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614936
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.269	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.003	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 105 S AVE
Sampled: 06/06/12 at 07:30 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614937
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.103	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.001	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 1502 JACKSON ST
Sampled: 06/13/12 at 08:15 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614938
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.654	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.030	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 2340 BALDWIN ST
Sampled: 06/08/12 at 06:00 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614939
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.132	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.001	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 1006 McNENNY DR
Sampled: 06/07/12 at 05:30 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614940
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.171	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.001	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Ristau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 1307 FULTON ST
Sampled: 06/06/12 at 05:00 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614941
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.064	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.001	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 2120 BALDWIN ST
Sampled: 06/08/12 at 05:30 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614942
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.174	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	< 0.001	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 515 MAIN ST
Sampled: 06/10/12 at 12:30 PM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614943
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.112	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.002	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 1507 JUNCTION
Sampled: 06/08/12 at 06:30 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614944
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.166	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	< 0.001	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 1751 ELLEN ST
Sampled: 06/06/12 at 08:30 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614945
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.148	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.001	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 2002 SUNSET ST
Sampled: 06/05/12 at 09:00 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614946
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.111	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.002	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 1510 JACKSON ST
Sampled: 06/11/12 at 06:30 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614947
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.103	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.002	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 1424 SPRUCE ST
Sampled: 06/06/12 at 07:30 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614948
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	< 0.005	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	< 0.001	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 604 WEBER DR
Sampled: 06/08/12 at 06:53 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614949
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.173	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.004	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 1229 SPRUCE ST
Sampled: 06/07/12 at 05:45 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614950
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.026	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	< 0.001	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 1814 DAVENPORT
Sampled: 06/05/12 at 03:15 PM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614951
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.186	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.002	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 1205 CEDAR DR
Sampled: 06/07/12 at 06:15 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614952
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.189	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	0.002	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM

MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: 913 WOODLAND DR
Sampled: 06/05/12 at 06:15 AM
by Resident
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

DALE OLSON
STURGIS WATER COMPANY
1040 2ND ST. SUITE 102
STURGIS, SD 57785

Lab ID#: 20120614953
Received: 06/14/12 at 10:48 AM
by Kate Shreves
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date	
Metals - Total								
Copper (Cu)	0.098	mg/L	10	0.0001	0.005	EPA 200.8	EJF	06/20/12
Lead (Pb)	< 0.001	mg/L	10	0.0009	0.001	EPA 200.8	EJF	06/20/12

Approved By: Steve Pistau

Approved On: 6/21/2012 8:28:31 AM