



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: Not Indicated
Sampled: 05/19/20 at 12:00 AM
by Russ Abernathy
Sample Matrix: Water

Lab ID#: 20200519831
Received: 05/19/20 at 12:00 PM
by Jennifer Hill
Account: 8392 - Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Physical Properties							
Hardness	247	mg/L	1			SM 2340 B	SCR 05/20/20
Metals - Dissolved							
Calcium (Ca)	64.0	mg/L	3	0.296	3.00	SM 3111 B	TMS 05/20/20
Magnesium (Mg)	21.1	mg/L	1	0.099	0.500	SM 3111 B	TMS 05/20/20

Report Approved By:

Steve Disten

Report Approved On: 5/20/2020 12:43:26 PM

14.43 Grains per gallon





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: **BHSS**
Purpose: Routine
EPA Number: 0321

Sturgis

Sampled: 09/08/20 at 09:45 AM
by Brant Ager
Sample Matrix: Water

Lab ID#: 20200908910
Received: 09/08/20 at 11:13 AM
by Jennifer Hill
Account: 8392 - Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Volatile							
Bromodichloromethane	2.46	µg/L	1	0.058	0.500	EPA 524.2	RAM 09/11/20
Bromoform	0.593	µg/L	1	0.074	0.500	EPA 524.2	RAM 09/11/20
Chlorodibromomethane	2.18	µg/L	1	0.050	0.500	EPA 524.2	RAM 09/11/20
Chloroform	1.67	µg/L	1	0.058	0.500	EPA 524.2	RAM 09/11/20
Calculated Totals							
Total Haloacetic Acids	< 15.0	µg/L	1	0.729	15.0	EPA 552.2	EJF 09/16/20
Total Trihalomethanes	6.90	µg/L	1			EPA 524.2	RAM 09/14/20
Semi-Volatile							
Dibromoacetic acid	< 2.50	µg/L	1	0.234	2.50	EPA 552.2	EJF 09/16/20
Dichloroacetic acid	< 2.50	µg/L	1	0.153	2.50	EPA 552.2	EJF 09/16/20
Monobromoacetic acid	< 2.50	µg/L	1	0.237	2.50	EPA 552.2	EJF 09/16/20
Monochloroacetic acid	< 5.00	µg/L	1	0.445	5.00	EPA 552.2	EJF 09/16/20
Trichloroacetic acid	< 2.50	µg/L	1	0.119	2.50	EPA 552.2	EJF 09/16/20

Report Approved By:

Steve Distau

Report Approved On: 9/21/2020 2:15:51 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: WELL #5
Sampled: 11/17/20 at 07:30 AM
by Todd Youngberg

Purpose: Routine
EPA Number: 0321
Sturgis

Sample Matrix: Water

Lab ID#: 20201117901
Received: 11/17/20 at 09:30 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter Result Units DF MDL PQL Method Analyst/Date

Non-Metallics

Nitrogen, Nitrate (NO3)	0.611	mg/L	10	0.090	0.500	SM 4500-NO3 F	BLL	11/18/20
Nitrogen, Nitrite (NO2)	< 0.050	mg/L	1	0.005	0.050	SM 4500-NO2 B	BLL	11/18/20

Approved By: Steve Pistau

Approved On: 11/20/2020 10:19:52 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: WELL #7
Sampled: 11/17/20 at 08:00 AM
by Todd Youngberg

Purpose: Routine
EPA Number: 0321
Sturgis

Sample Matrix: Water

Lab ID#: 20201117902
Received: 11/17/20 at 09:30 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter Result Units DF MDL PQL Method Analyst/Date

Non-Metallics

Nitrogen, Nitrate (NO3)	0.730	mg/L	10	0.090	0.500	SM 4500-NO3 F	BLL	11/18/20
Nitrogen, Nitrite (NO2)	< 0.050	mg/L	1	0.005	0.050	SM 4500-NO2 B	BLL	11/18/20

Approved By: Steve Distau

Approved On: 11/20/2020 10:19:52 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: WELL #3
Sampled: 11/17/20 at 08:40 AM
by Todd Youngberg
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

Lab ID#: 20201117903
Received: 11/17/20 at 09:30 AM
by Sarah Ahlers
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Nitrogen, Nitrate (NO3)	0.430	mg/L	1	0.009	0.050	SM 4500-NO3 F	BLL 11/18/20
Nitrogen, Nitrite (NO2)	< 0.050	mg/L	1	0.005	0.050	SM 4500-NO2 B	BLL 11/18/20

Approved By: Steve Pistau

Approved On: 11/20/2020 10:19:52 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
 (605) 348-0111 -- www.thechemistrylab.com

NOV 18 2020

Received: 11/17/20 at 12:00 PM
 by Sarah Ahlers
 Account: 9504
 A & L Contractors LLC.

A & L CONTRACTORS LLC
 3122 EAST FAIRGROUND LOOP
 SPEARFISH, SD 57783

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Vanocker Rd. Sturgis	Hydrant #1	11/17/20 10:52 AM	Result	Result		JMH 11/17/20	P-2020-11-17-01
	Vanocker Rd. Sturgis	Hydrant #2	11/17/20 11:09 AM	Result	Result		JME 11/17/2020	P-2020-11-17-02

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 11/18/2020 2:14:08 PM

DATE PRINTED: 11/18/2020 02:31 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 11/16/20 at 01:00 PM
by System Account
Account: 9504
A & L Contractors LLC.

A & L CONTRACTORS LLC
3122 EAST FAIRGROUND LOOP
SPEARFISH, SD 57783

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Vanocor Rd. Sturgis ₁	Hydrant 1	11/16/20 10:23 AM	Absent	Absent		SM 11/16/20	3521015411
	Vanocor Rd. Sturgis ₁	Hydrant 2	11/16/20 09:55 AM	Absent	Absent		SM 11/16/20	3521015411

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 11/17/2020 1:35:41 PM

DATE PRINTED: 11/17/2020 02:01 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

6001 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 10/22/20 at 03:30 PM
by System Account
Account: 9471
MainLine Contracting Inc.

TY OR REID
MAINLINE CONTRACTING INC.
P.O. BOX 3448
RAPID CITY, SD 57709

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Herman St. 1		10/22/20 03:00 PM	Absent	Absent		JMH 10/22/2020	20201022835

Harman St.

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 10/23/2020 1:10:49 PM

DATE PRINTED: 10/23/2020 01:20 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 10/26/20 at 10:45 AM
by System Account
Account: 9471
MainLine Contracting Inc.

TY OR REID
MAINLINE CONTRACTING INC.
P.O. BOX 3448
RAPID CITY, SD 57709

DRINKING WATER REPORT

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	6" Main - Sturgis ₁		10/26/20 09:30 AM	Absent	Absent		JMH 10/26/2020	20201026804

Harmon St.

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 10/27/2020 1:37:42 PM

DATE PRINTED: 10/27/2020 01:52 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)
Sampled: 12/08/20 at 06:45 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water
Lab ID#: 20201208815
Received: 12/08/20 at 08:40 AM
by Sarah Ahlers
Account: 8392
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.529	mg/L	1	0.010	0.015	SM 4500 F-C	TMN 12/09/20
Field Test							
Field Fluoride	0.850	mg/L	1			Field Fluoride	JMH 12/09/20

Approved By: Steve Distau

Approved On: 12/10/2020 7:56:56 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Butte Ridge Building E
(1900 Ellen St.)
Sampled: 12/01/20 at 08:01 AM
by Brant
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20201201953
Received: 12/01/20 at 12:30 PM
by Sarah Ahlers

Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.557	mg/L	1	0.010	0.015	SM 4500 F-C	TMN 12/02/20
Field Test							
Field Fluoride	0.930	mg/L	1			Field Fluoride	SYS 12/02/20

Approved By: Steve Distau

Approved On: 12/3/2020 11:48:28 AM



3381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Ford Regulator (2418 Junction)
Sampled: 11/16/20 at 06:50 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Matrix: Water

Lab ID#: 20201117820
Received: 11/17/20 at 09:30 AM
by Sarah Ahlers
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.487	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 11/18/20
Field Test							
Field Fluoride	0.690	mg/L	1			Field Fluoride	JMH 11/18/20

Approved By: Steve Ristan

Approved On: 11/19/2020 9:11:23 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Butte Ridge Building E
(1900 Ellen St.)
Sampled: 11/10/20 at 08:03 AM
by Wyatt Hix
Purpose: Routine
EPA
Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20201110828
Received: 11/10/20 at 10:00 AM
by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	1.43	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 11/11/20
Field Test							
Field Fluoride	1.33	mg/L	1			Field Fluoride	JMH 11/11/20

Approved By: Steve Distau

Approved On: 11/11/2020 2:04:19 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: **Pete Lien & Sons (2025 Sherman)**

Purpose: Routine
EPA Number: 0321

Sturgis

Sampled: 10/20/20 at 07:01 AM
by Brant Ager

Sample Matrix: Water

Lab ID#: 20201020801
Received: 10/20/20 at 09:20 AM
by Jennifer Hill

Account: 8392 - Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<u>Non-Metallics</u>							
Fluoride	1.34	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 10/20/20

Report Approved By:

Steve Distau

Report Approved On: 10/22/2020 1:42:30 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: **Sturgis Water Shop
(2901 Vanocker
Canyon Rd)**
Purpose: Routine
EPA Number: 0321
Sturgis
Sampled: 10/14/20 at 06:45 AM
by R. Abernathy
Sample Matrix: Water
Lab ID#: 20201014830
Received: 10/14/20 at 10:10 AM
by Sarah Ahlers
Account: 8392 - Sturgis Water Company


RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.506	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 10/20/20
Field Test							
Field Fluoride	0.740	mg/L	1			Field Fluoride	SYS 10/15/20

Report Approved By:

Steve Pistau


Report Approved On: 10/20/2020 11:53:09 AM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785



Sample Site: Ford Regulator (2418 Junction)

Purpose: Routine
EPA Number: 0321

Sturgis

Sampled: 09/16/20 at 07:45 AM
by Brant Ager

Sample Matrix: Water

Lab ID#: 20200916836
Received: 09/16/20 at 11:00 AM
by System Account

Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.546	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 09/18/20

Report Approved By:

Jennifer Hill

Report Approved On: 9/18/2020 1:40:53 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: Butte Ridge Building E
(1900 Ellen St.)

Purpose: Routine
EPA Number: 0321

Sturgis

Sampled: 09/08/20 at 07:47 AM
by Brant

Sample Matrix: Water

Lab ID#: 20200908838
Received: 09/08/20 at 11:13 AM
by Jennifer Hill

Account: 8392 - Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	1.26	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 09/10/20
Field Test							
Field Fluoride	1.30	mg/L	1			Field Fluoride	SYS 09/09/20

Report Approved By:

Steve Distau

Report Approved On: 9/10/2020 3:53:28 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785
Test 8/20/20

Sample Site: Rasmussen Mech. Services (3590 Mayor Ave)
Purpose: Routine
EPA Number: 0321
Sampled: 08/18/20 at 08:31 AM by Wyatt
Sample Matrix: Water
Lab ID#: 20200818846
Received: 08/18/20 at 12:20 PM by Steve Ristau
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	1.28	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 08/19/20
Field Test							
Field Fluoride	1.34	mg/L	1			Field Fluoride	SYS 08/19/20

Report Approved By:

Steve Ristau

Report Approved On: 8/20/2020 8:42:04 AM

8/20/20



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785


Sample Site: Sturgis Parks Dept.
Shop (1920 Ballpark A)
Purpose: Routine
EPA Number: 0321
Sturgis
Sampled: 08/05/20 at 08:20 AM
by Russ Abernathy
Sample Matrix: Water
Lab ID#: 20200805860
Received: 08/05/20 at 10:30 AM
by Sarah Ahlers
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.584	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 08/05/20
Field Test							
Field Fluoride	0.740	mg/L	1			Field Fluoride	JMH 08/06/20

Report Approved By:

Steve Pistan

Report Approved On: 8/6/2020 1:46:43 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Ford Regulator (2418 Junction) 14
Purpose: Routine
EPA Number: 0321
Sampled: 07/23/20 at 10:30 AM by Russ Abernatny Sturgis
Sample Matrix: Water
Lab ID#: 20200723843
Received: 07/23/20 at 11:35 AM by Julie Muzzy
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.471	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 07/24/20
Field Test							
Field Fluoride	0.730	mg/L	1			Field Fluoride	JMH 07/24/20

Report Approved By:

Steve Pistau

Report Approved On: 7/28/2020 9:09:05 AM

(Faint circular stamp)



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: **City Waterman**
Purpose: Routine
EPA Number: 0321

Sturgis

Sampled: 07/15/20 at 11:20 AM
by Russ Abernathy
Sample Matrix: Water

Lab ID#: 20200715886
Received: 07/15/20 at 01:30 PM
by Jennifer Hill
Account: 8392 - Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.635	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 07/17/20
Field Test							
Field Fluoride	0.750	mg/L	1			Field Fluoride	JMH 07/16/20

Report Approved By:

Steve Distau

Report Approved On: 7/17/2020 11:00:55 AM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Community Center
(1401 Lazelle)
Purpose: Routine
EPA Number: 0321
Sturgis
Sampled: 06/25/20 at 02:13 PM
by Wyatt Hix
Sample Matrix: Water
Lab ID#: 20200625886
Received: 06/25/20 at 03:29 PM
by Jennifer Hill
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.759	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 06/30/20
Field Test							
Field Fluoride	0.830	mg/L	1			Field Fluoride	JMH 06/26/20

Report Approved By:

Steve Distau

Report Approved On: 6/30/2020 10:47:53 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Sturgis Parks Dept.
Shop (1920 Ballpark A)
Purpose: Routine
EPA Number: 0321
Sturgis
Sampled: 06/10/20 at 10:10 AM
by Wyatt Hix
Sample Matrix: Water
Lab ID#: 20200610838
Received: 06/10/20 at 02:00 PM
by Jacey Merkle
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.618	mg/L	1	0.010	0.015	SM 4500 F-C	JMH 06/11/20
Field Test							
Field Fluoride	0.930	mg/L	1			Field Fluoride	JMH 06/11/20

Report Approved By:

Steve Distau

Report Approved On: 6/11/2020 2:41:19 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Rasmussen Mech. Services (3590 Mayor Ave)

Purpose: Routine
EPA Number: 0321

Sturgis

Sampled: 05/19/20 at 10:30 AM
by Russ Abernathy

Sample Matrix: Water

Lab ID#: 20200519830
Received: 05/19/20 at 12:00 PM
by Bobbie Laurenz

Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
Non-Metallics							
Fluoride	0.589	mg/L	1	0.010	0.015	SM 4500 F-C	SAA 05/20/20
Field Test							
Field Fluoride	0.800	mg/L	1			Field Fluoride	JMH 05/20/20

Report Approved By:

Steve Distau

Report Approved On: 5/20/2020 2:08:37 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Sturgis Parks Dept.
Shop (1920 Ballpark A)
Purpose: Routine
EPA Number: 0321
Sampled: 05/04/20 at 08:20 AM
by Russ Abernathy
Sample Matrix: Water
Lab ID#: 20200504825
Received: 05/04/20 at 11:00 AM
by Bobbie Laurenz
Account: 8392 - Sturgis Water Company

Sturgis

Parameter	Result	Units	DF	Method	Analyst/Date
Non-Metallics					
Fluoride	0.577	mg/L	1	SM 4500 F-C	SAA 05/05/20
Field Test					
Field Fluoride	0.800	mg/L	1	Field Fluoride	JMH 05/05/20

Report Approved By:

Steve Distau

Report Approved On: 5/5/2020 3:01:23 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Community Center
(1401 Lazelle)
Purpose: Routine
EPA Number: 0321
Sturgis
Sampled: 04/20/20 at 11:15 AM
by Wyatt Hix
Sample Matrix: Water
Lab ID#: 20200420814
Received: 04/20/20 at 01:15 PM
by Jennifer Hill
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	Method	Analyst/Date
Non-Metallics					
Fluoride	0.496	mg/L	1	SM 4500 F-C	SAA 04/20/20
Field Test					
Field Fluoride	0.820	mg/L	1	Field Fluoride	JMH 04/21/20

Report Approved By:

Steve Distau

Report Approved On: 4/21/2020 1:16:08 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: City Waterman
Purpose: Routine
EPA Number: 0321

Sturgis

Sampled: 04/13/20 at 11:10 AM
by Wyatt Hix
Sample Matrix: Water

Lab ID#: 20200413819
Received: 04/13/20 at 12:30 PM
by Jennifer Hill
Account: 8392 - Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	Method	Analyst/Date
Non-Metallics					
Fluoride	0.452	mg/L	1	SM 4500 F-C	SAA 04/15/20
Field Test					
Field Fluoride	0.790	mg/L	1	Field Fluoride	JMH 04/13/20

Report Approved By:

Steve Distau

Report Approved On: 4/15/2020 11:23:51 AM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Rasmussen Mech.
Services (3590 Mayor
Ave)

Purpose: Routine
EPA Number: 0321

Sampled: 03/12/20 at 10:00 AM
by R. Abernathy

Sample Matrix: Water

Lab ID#: 20200312845
Received: 03/12/20 at 10:44 AM
by Steve Ristau

Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	Method	Analyst/Date
<u>Non-Metallics</u>					
Fluoride	0.680	mg/L	1	SM 4500 F-C	SAA 03/17/20

Report Approved By:

Steve Ristau

Report Approved On: 3/17/2020 1:34:31 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: Sturgis City Hall (1040 Harley-Davidson Way)
Purpose: Routine
EPA Number: 0321
Sampled: 03/04/20 at 09:00 AM
by R. Abernathy
Sample Matrix: Water
Lab ID#: 20200304848
Received: 03/04/20 at 10:42 AM
by Sarah Ahlers
Account: 8392 - Sturgis Water Company

Sturgis

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	Method	Analyst/Date
<u>Non-Metallics</u>					
Fluoride	0.455	mg/L	1	SM 4500 F-C	SAA 03/05/20

Report Approved By:

Steve Distau

Report Approved On: 3/5/2020 3:59:13 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sturgis Water Shop
(2901 Vanocker
Canyon Rd)

Sample Site:
Purpose: Routine
EPA Number: 0321

Sturgis

Sampled: 02/20/20 at 11:30 AM
by Brad Deutsch
Sample Matrix: Water

Lab ID#: 20200220828
Received: 02/20/20 at 12:35 PM
by Jennifer Hill
Account: 8392 - Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Parameter	Result	Units	DF	Method	Analyst/Date
<u>Non-Metallics</u>					
Fluoride	0.615	mg/L	1	SM 4500 F-C	SAA 02/26/20

Report Approved By:

Steve Distau

Report Approved On: 2/26/2020 2:03:40 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Rasmussen Mech.
Services (3590 Mayor
Ave)

Purpose: Routine
EPA Number: 0321

Sampled: 02/14/20 at 11:20 AM
by Wyatt Hix

Sample Matrix: Water

Lab ID#: 20200214810
Received: 02/14/20 at 01:10 PM
by Jennifer Hill

Account: 8392 - Sturgis Water Company

Sturgis

Parameter	Result	Units	DF	Method	Analyst/Date
<u>Non-Metallics</u>					
Fluoride	0.641	mg/L	1	SM 4500 F-C	SAA 02/20/20

Report Approved By:

Steve Distau

Report Approved On: 2/20/2020 12:36:38 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

BRAD DEUTSCH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Sturgis Parks Dept.
Shop (1920 Ballpark A)
Purpose: Routine
EPA Number: 0321
Sturgis
Sampled: 01/28/20 at 10:30 AM
by Russell Abernathy
Sample Matrix: Water
Lab ID#: 20200128890
Received: 01/28/20 at 12:00 PM
by Jennifer Hill
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	Method	Analyst/Date
<u>Non-Metallics</u>					
Fluoride	0.684	mg/L	1	SM 4500 F-C	SAA 02/03/20

Report Approved By:

Steve Pistan

Report Approved On: 2/4/2020 2:59:43 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

BRAD DEUTSCH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Sturgis Water Shop
(2901 Vanocker Canyon Rd)
Purpose: Routine
EPA Number: 0321
Sturgis
Sampled: 01/21/20 at 10:33 AM
by Brad Deutsch
Sample Matrix: Water
Lab ID#: 20200121818
Received: 01/21/20 at 12:36 PM
by Sarah Ahlers
Account: 8392 - Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<u>Non-Metallics</u>							
Fluoride	0.666	mg/L	1	0.013	0.050	SM 4500 F-C	SAA 01/22/20

Report Approved By:

Jennifer Hill

Report Approved On: 1/23/2020 3:31:15 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

281 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 12/08/20 at 08:40 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	000	City Waterman		12/08/2020 07:30 AM	Absent	Absent	0.6 mg/L		JMH 12/08/2020	20201208810
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		12/08/2020 06:45 AM	Absent	Absent	0.9 mg/L		JMH 12/08/2020	20201208811
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		12/08/2020 07:10 AM	Absent	Absent	0.5 mg/L		JMH 12/08/2020	20201208812

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 12/10/2020 7:56:56 AM

DATE PRINTED: 12/10/2020 08:56 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2281 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 12/01/20 at 12:30 PM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	006	Butte Ridge Building E (1900 Ellen St.)		12/01/2020 08:07 AM	Absent	Absent	0.6 mg/L		SAA 12/01/2020	20201201845
0321	007	Community Center (1401 Lazelle)		12/01/2020 08:20 AM	Absent	Absent	0.62 mg/L		SAA 12/01/2020	20201201846
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		12/01/2020 08:35 AM	Absent	Absent	0.53 mg/L		SAA 12/01/2020	20201201847
0321	014	Ford Regulator (2418 Junction)		12/01/2020 08:50 AM	Absent	Absent	0.48 mg/L		SAA 12/01/2020	20201201848

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

12/2/2020 1:56:27 PM

DATE PRINTED:

12/02/2020 02:14 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 11/17/20 at 09:30 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		11/17/2020 07:15 AM	Absent	Absent	0.52 mg/L		JMH 11/17/2020	20201117824
0321	005	Pete Lien & Sons (2025 Sherman)		11/17/2020 08:30 AM	Absent	Absent	0.57 mg/L		JMH 11/17/2020	20201117825
0321	014	Ford Regulator (2418 Junction)		11/17/2020 06:50 AM	Absent	Absent	0.4 mg/L		JMH 11/17/2020	20201117826

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 11/18/2020 2:14:08 PM

DATE PRINTED: 11/18/2020 02:31 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 11/10/20 at 10:00 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	006	Butte Ridge Building E (1900 Ellen St.)		11/10/2020 07:59 AM	Absent	Absent	0.74 mg/L		JMH 11/10/2020	20201110824
0321	007	Community Center (1401 Lazelle)		11/10/2020 08:21 AM	Absent	Absent	0.96 mg/L		JMH 11/10/2020	20201110825
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		11/10/2020 07:08 AM	Absent	Absent	0.35 mg/L		JMH 11/10/2020	20201110826
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		11/10/2020 07:38 AM	Absent	Absent	0.47 mg/L		JMH 11/10/2020	20201110827

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

11/11/2020 2:04:19 PM

DATE PRINTED:

11/11/2020 02:12 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 10/20/20 at 09:20 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		10/20/2020 07:25 AM	Absent	Absent	0.3 mg/L		JMH 10/20/2020	20201020814
0321	005	Pete Lien & Sons (2025 Sherman)		10/20/2020 06:58 AM	Absent	Absent	0.73 mg/L		JMH 10/20/2020	20201020815
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		10/20/2020 07:54 AM	Absent	Absent	0.56 mg/L		JMH 10/20/2020	20201020816

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

10/21/2020 1:12:27 PM

DATE PRINTED:

10/21/2020 01:12 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 10/14/20 at 10:10 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	007	Community Center (1401 Lazelle)		10/14/2020 08:00 AM	Absent	Absent	0.78 mg/L		SAA 10/14/2020	20201014825
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		10/14/2020 06:45 AM	Absent	Absent	0.59 mg/L		SAA 10/14/2020	20201014826
0321	014	Ford Regulator (2418 Junction)		10/14/2020 07:25 AM	Absent	Absent	0.6 mg/L		SAA 10/14/2020	20201014827
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		10/14/2020 07:10 AM	Absent	Absent	0.59 mg/L		SAA 10/14/2020	20201014828

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

10/15/2020 2:49:18 PM

DATE PRINTED:

10/15/2020 02:49 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 09/08/20 at 11:13 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)								
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		09/08/2020 08:29 AM	Absent	Absent	0.79 mg/L		JMH 09/08/2020	20200908813
0321	006	Butte Ridge Building E (1900 Ellen St.)		09/08/2020 08:42 AM	Absent	Absent	0.44 mg/L		JMH 09/08/2020	20200908814
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		09/08/2020 07:53 AM	Absent	Absent	0.72 mg/L		JMH 09/08/2020	20200908815
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		09/08/2020 08:12 AM	Absent	Absent	0.49 mg/L		JMH 09/08/2020	20200908816

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

9/9/2020 2:44:30 PM

DATE PRINTED:

09/09/2020 02:44 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 08/18/20 at 12:50 PM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		08/18/2020 09:16 AM	Absent	Absent	0.51 mg/L		SAA 08/18/2020	20200818830
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		08/18/2020 08:17 AM	Absent	Absent	0.51 mg/L		SAA 08/18/2020	20200818831
0321	006	Butte Ridge Building E (1900 Ellen St.)		08/18/2020 08:54 AM	Absent	Absent	0.75 mg/L		SAA 08/18/2020	20200818832

REPORT APPROVED BY:

Steve Pistan

REPORT APPROVED DATE:

8/20/2020 8:42:04 AM

DATE PRINTED:

08/20/2020 08:42 AM





MIDCONTINENT

TESTING LABORATORIES, INC

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 08/05/20 at 10:30 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	007	Community Center (1401 Lazelle)		08/05/2020 09:05 AM	Absent	Absent	0.8 mg/L		JMH 08/05/2020	20200805815
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		08/05/2020 08:40 AM	Absent	Absent	0.67 mg/L		JMH 08/05/2020	20200805816
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		08/05/2020 07:55 AM	Absent	Absent	1.19 mg/L		JMH 08/05/2020	20200805817
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		08/05/2020 08:20 AM	Absent	Absent	0.7 mg/L		JMH 08/05/2020	20200805818

REPORT APPROVED BY:

Steve Pistan

REPORT APPROVED DATE:

8/6/2020 2:09:38 PM

DATE PRINTED:

08/06/2020 02:09 PM





MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 07/23/20 at 11:35 AM
by Julie Muzzy

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		07/23/2020 09:10 AM	Absent	Absent	0.59 mg/L		JMH 07/23/2020	20200723826
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		07/23/2020 08:00 AM	Absent	Absent	0.59 mg/L		JMH 07/23/2020	20200723827
0321	014	Ford Regulator (2418 Junction)		07/23/2020 07:45 AM	Absent	Absent	0.57 mg/L		JMH 07/23/2020	20200723828
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		07/23/2020 08:50 AM	Absent	Absent	0.64 mg/L		JMH 07/23/2020	20200723829

REPORT APPROVED BY:


Steve Distau

REPORT APPROVED DATE:

7/28/2020 9:09:04 AM

DATE PRINTED:

07/28/2020 09:10 AM





MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 07/15/20 at 01:30 PM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	000	City Waterman		07/15/2020 11:20 AM	Absent	Absent	0.68 mg/L		JMH 07/15/2020	20200715845
0321	007	Community Center (1401 Lazelle)		07/15/2020 12:00 AM	Absent	Absent	0.61 mg/L		JMH 07/15/2020	20200715846
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		07/15/2020 10:00 AM	Absent	Absent	0.64 mg/L		JMH 07/15/2020	20200715847

REPORT APPROVED BY:

Steve Pistau

REPORT APPROVED DATE:

7/17/2020 9:52:37 AM

DATE PRINTED:

07/17/2020 09:55 AM





MIDCONTINENT
TESTING LABORATORIES, INC.


Purpose: Routine

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 06/25/20 at 03:29 PM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785



MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	007	Community Center (1401 Lazelle)		06/25/2020 02:15 PM	Absent	Absent	0.76 mg/L		JMH 06/25/2020	20200625880
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		06/25/2020 12:40 PM	Absent	Absent	0.55 mg/L		JMH 06/25/2020	20200625881
0321	014	Ford Regulator (2418 Junction)		06/25/2020 12:08 PM	Absent	Absent	0.68 mg/L		JMH 06/25/2020	20200625882

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

6/26/2020 1:52:41 PM

DATE PRINTED:

06/26/2020 01:52 PM



MIDCONTINENT
TESTING LABORATORIES, INC


2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 06/10/20 at 02:00 PM
by Jacey Merkle

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785



MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		06/10/2020 11:10 AM	Absent	Absent	0.43 mg/L		JMH 06/10/2020	20200610834
0321	006	Butte Ridge Building E (1900 Ellen St.)		06/10/2020 10:44 AM	Absent	Absent	0.4 mg/L		JMH 06/10/2020	20200610835
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		06/10/2020 09:34 AM	Absent	Absent	0.57 mg/L		JMH 06/10/2020	20200610836
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		06/10/2020 10:16 AM	Absent	Absent	0.6 mg/L		JMH 06/10/2020	20200610837

REPORT APPROVED BY:

Steve Pistau

REPORT APPROVED DATE:

6/11/2020 2:41:19 PM

DATE PRINTED:

06/11/2020 02:41 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 05/19/20 at 12:00 PM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		05/19/2020 10:30 AM	Absent	Absent	0.39 mg/L		JMH 05/19/2020	20200519832
0321	007	Community Center (1401 Lazelle)		05/19/2020 09:50 AM	Absent	Absent	0.57 mg/L		JMH 05/19/2020	20200519833
0321	010	Schneider/Beckwith Dental (1245 Sherman)		05/19/2020 10:00 AM	Absent	Absent	0.43 mg/L		JMH 05/19/2020	20200519834

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

5/20/2020 12:43:26 PM

DATE PRINTED:

05/20/2020 12:43 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 05/04/20 at 12:30 PM
by Steve Ristau

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		05/04/2020 10:05 AM	Absent	Absent	0.48 mg/L		SCR 05/04/2020	20200504820
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		05/04/2020 09:50 AM	Absent	Absent	0.69 mg/L		SCR 05/04/2020	20200504821
0321	014	Ford Regulator (2418 Junction)		05/04/2020 08:35 AM	Absent	Absent	0.63 mg/L		SCR 05/04/2020	20200504822
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		05/04/2020 08:20 AM	Absent	Absent	0.6 mg/L		SCR 05/04/2020	20200504823

REPORT APPROVED BY:

Steve Ristau

REPORT APPROVED DATE:

5/5/2020 3:01:23 PM

DATE PRINTED:

05/05/2020 03:01 PM





MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 04/20/20 at 01:15 PM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	003	Speedy Lube (2205 Park Ave)		04/20/2020 10:48 AM	Absent	Absent	0.64 mg/L		JMH 04/20/2020	20200420815
0321	006	Butte Ridge Building E (1900 Ellen St.)		04/20/2020 10:30 AM	Absent	Absent	0.57 mg/L		JMH 04/20/2020	20200420816
0321	007	Community Center (1401 Lazelle)		04/20/2020 11:23 AM	Absent	Absent	0.68 mg/L		JMH 04/20/2020	20200420817

REPORT APPROVED BY:

Steve Ristan

REPORT APPROVED DATE:

4/21/2020 1:16:08 PM

DATE PRINTED:

04/21/2020 01:16 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 04/13/20 at 12:30 PM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	000	City Waterman		04/13/2020 10:28 AM	Absent	Absent	0.7 mg/L		JMH 04/13/2020	20200413815
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		04/13/2020 10:12 AM	Absent	Absent	0.57 mg/L		JMH 04/13/2020	20200413816
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		04/13/2020 08:50 AM	Absent	Absent	0.77 mg/L		JMH 04/13/2020	20200413817
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		04/13/2020 09:20 AM	Absent	Absent	0.62 mg/L		JMH 04/13/2020	20200413818

REPORT APPROVED BY:


Steve Distau

REPORT APPROVED DATE:

4/14/2020 1:47:46 PM

DATE PRINTED:

04/14/2020 01:47 PM





MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 03/12/20 at 10:44 AM
by Steve Ristau

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	002	National Guard (701 14th St.)		03/12/2020 08:00 AM	Absent	Absent	0.44 mg/L		SAA 03/12/2020	20200312806
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		03/12/2020 08:35 AM	Absent	Absent	0.91 mg/L		SAA 03/12/2020	20200312807
0321	014	Ford Regulator (2418 Junction)		03/12/2020 07:50 AM	Absent	Absent	0.68 mg/L		SAA 03/12/2020	20200312808

REPORT APPROVED BY:

Steve Ristau

REPORT APPROVED DATE:

3/13/2020 2:55:20 PM

DATE PRINTED:

03/13/2020 02:55 PM





MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 03/04/20 at 10:42 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	007	Community Center (1401 Lazelle)		03/04/2020 08:15 AM	Absent	Absent	0.65 mg/L		JMH 03/04/2020	20200304828
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		03/04/2020 09:00 AM	Absent	Absent	0.63 mg/L		JMH 03/04/2020	20200304829
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		03/04/2020 07:30 AM	Absent	Absent	0.78 mg/L		JMH 03/04/2020	20200304830
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		03/04/2020 08:00 AM	Absent	Absent	0.49 mg/L		JMH 03/04/2020	20200304831

REPORT APPROVED BY:

Steve Ristau

REPORT APPROVED DATE:

3/5/2020 3:59:13 PM

DATE PRINTED:

03/05/2020 04:00 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 02/20/20 at 12:35 PM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		02/20/2020 08:30 AM	Absent	Absent	0.69 mg/L		JMH 02/20/2020	20200220825
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		02/20/2020 10:20 AM	Absent	Absent	0.83 mg/L		JMH 02/20/2020	20200220826
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		02/20/2020 08:11 AM	Absent	Absent	0.42 mg/L		JMH 02/20/2020	20200220827

REPORT APPROVED BY:

Steve Pistau

REPORT APPROVED DATE:

2/21/2020 12:47:05 PM

DATE PRINTED:

02/21/2020 12:47 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 02/14/20 at 01:10 PM
by Jennifer Hill

Account: 8392
Sturgis Water Company

BRAD DEUTSCH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	002	National Guard (701 14th St.)		02/14/2020 11:00 AM	Absent	Absent	0.46 mg/L		JMH 02/14/2020	20200214806
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		02/14/2020 11:27 AM	Absent	Absent	0.45 mg/L		JMH 02/14/2020	20200214807
0321	009	Loftus Dental Office (866 Lazelle)		02/14/2020 10:11 AM	Absent	Absent	0.42 mg/L		JMH 02/14/2020	20200214808
0321	011	Sturgis Physical Therapy (1530 Junction)		02/14/2020 10:34 AM	Absent	Absent	0.44 mg/L		JMH 02/14/2020	20200214809

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

2/18/2020 10:47:54 AM

DATE PRINTED:

02/18/2020 10:47 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 01/28/20 at 12:00 PM
by Jennifer Hill

Account: 8392
Sturgis Water Company

BRAD DEUTSCH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		01/28/2020 08:20 AM	Absent	Absent	0.63 mg/L		JMH 01/28/2020	20200128804
0321	007	Community Center (1401 Lazelle)		01/28/2020 08:40 AM	Absent	Absent	0.82 mg/L		JMH 01/28/2020	20200128805
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		01/28/2020 08:50 AM	Absent	Absent	0.72 mg/L		JMH 01/28/2020	20200128806
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		01/28/2020 10:30 AM	Absent	Absent	0.74 mg/L		JMH 01/28/2020	20200128807

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

1/30/2020 8:38:36 AM

DATE PRINTED:

01/30/2020 08:38 AM





MIDCONTINENT

TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 01/21/20 at 12:36 PM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

BRAD DEUTSCH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		01/21/2020 11:07 AM	Absent	Absent	0.9 mg/L		JMH 01/21/2020	20200121811
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		01/21/2020 10:32 AM	Absent	Absent	0.67 mg/L		JMH 01/21/2020	20200121812
0321	014	Ford Regulator (2418 Junction)		01/21/2020 10:21 AM	Absent	Absent	0.69 mg/L		JMH 01/21/2020	20200121813

REPORT APPROVED BY:

Jennifer Hill

REPORT APPROVED DATE:

1/23/2020 9:42:54 AM

DATE PRINTED:

01/23/2020 09:42 AM