



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 3110 Lazelle
Sampled: 07/23/21 at 07:00 AM
Sample Matrix: Water

Lab ID#: 20210729912
Received: 07/29/21 at 11:25 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|---------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.035 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/19/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/19/21 |

Approved By: Steve Distau

Approved On: 8/24/2021 9:01:45 AM

Not a compliance sample

Public Service



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: B.H. Special Services
Sampled: 08/17/21 at 08:35 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20210818925
Received: 08/18/21 at 09:35 AM
by Dean Aurand
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|---------------------------------|---------|-------|----|-------|-------|-----------|--------------|
| <u>Volatile</u> | | | | | | | |
| Bromodichloromethane | 0.814 | µg/L | 1 | 0.010 | 0.500 | EPA 524.2 | RAM 08/25/21 |
| Bromoform | < 0.500 | µg/L | 1 | 0.013 | 0.500 | EPA 524.2 | RAM 08/25/21 |
| Chlorodibromomethane | 0.829 | µg/L | 1 | 0.009 | 0.500 | EPA 524.2 | RAM 08/25/21 |
| Chloroform | < 0.500 | µg/L | 1 | 0.009 | 0.500 | EPA 524.2 | RAM 08/25/21 |
| <u>Calculated Totals</u> | | | | | | | |
| Total Haloacetic Acids | < 15.0 | µg/L | 1 | 0.729 | 15.0 | EPA 552.2 | SAC 08/26/21 |
| Total Trihalomethanes | < 2.00 | µg/L | 1 | 0.043 | 2.00 | EPA 524.2 | RAM 08/27/21 |
| <u>µmi-Volatile</u> | | | | | | | |
| Dibromoacetic acid | < 2.50 | µg/L | 1 | 0.234 | 2.50 | EPA 552.2 | SAC 08/26/21 |
| Dichloroacetic acid | < 2.50 | µg/L | 1 | 0.153 | 2.50 | EPA 552.2 | SAC 08/26/21 |
| Monobromoacetic acid | < 2.50 | µg/L | 1 | 0.237 | 2.50 | EPA 552.2 | SAC 08/26/21 |
| Monochloroacetic acid | < 5.00 | µg/L | 1 | 0.445 | 5.00 | EPA 552.2 | SAC 08/26/21 |
| Trichloroacetic acid | < 2.50 | µg/L | 1 | 0.119 | 2.50 | EPA 552.2 | SAC 08/26/21 |

Approved By: Steve Distau

Approved On: 8/31/2021 1:14:07 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1229 SPRUCE ST
Sampled: 09/15/21 at 06:35 AM
Purpose: Routine
EPA Number: 0321

Sample Matrix: Water Sturgis

Lab ID#: 20210920914
Received: 09/20/21 at 11:30 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|---------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.044 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 09/29/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 09/29/21 |

Approved By: Steve Distau

Approved On: 10/1/2021 10:50:54 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1205 MAPLE DR
Sampled: 07/23/21 at 05:30 AM
Purpose: Routine
EPA Number: 0321

Sample Matrix: Water Sturgis

Lab ID#: 20210729913
Received: 07/29/21 at 11:25 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|---------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.079 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/19/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/19/21 |

Approved By: Steve Distau

Approved On: 8/24/2021 9:01:45 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 2340 BALDWIN ST
Sampled: 07/29/21 at 07:00 AM
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20210729914
Received: 07/29/21 at 11:25 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date | |
|-----------------------|---------|-------|----|---------|-------|-----------|--------------|----------|
| Metals - Total | | | | | | | | |
| Copper (Cu) | 0.092 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA | 08/19/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA | 08/19/21 |

Approved By: Steve Pistau

Approved On: 8/24/2021 9:01:45 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1429 Pine St.
Sampled: 07/23/21 at 06:00 AM
Purpose: Routine
EPA Number: 0321

Sturgis
Sample Matrix: Water

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Lab ID#: 20210729915
Received: 07/29/21 at 11:25 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------|--------|-------|----|-----|-----|--------|--------------|
|-----------|--------|-------|----|-----|-----|--------|--------------|

Metals - Total

| | | | | | | | |
|-------------|---------|------|----|---------|-------|-----------|--------------|
| Copper (Cu) | 0.078 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/19/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/19/21 |

Approved By: Steve Pistau

Approved On: 8/24/2021 9:01:45 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1510 JACKSON ST
Sampled: 07/28/21 at 06:30 AM
Purpose: Routine
EPA Number: 0321

Sample Matrix: Water Sturgis

Lab ID#: 20210729916
Received: 07/29/21 at 11:25 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|--------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.121 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/19/21 |
| Lead (Pb) | 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/19/21 |

Approved By: Steve Distau

Approved On: 8/24/2021 9:01:45 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 2002 SUNSET ST
Sampled: 07/27/21 at 11:14 AM
Purpose: Routine
EPA Number: 0321

Sample Matrix: Water Sturgis

Lab ID#: 20210729917
Received: 07/29/21 at 11:25 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|--------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.322 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/19/21 |
| Lead (Pb) | 0.010 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/19/21 |

Approved By: Steve Distau

Approved On: 8/24/2021 9:01:45 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 632 WEBER DR
Sampled: 07/23/21 at 04:50 AM
Purpose: Routine
EPA Number: 0321

Sturgis
Sample Matrix: Water

Lab ID#: 20210729918
Received: 07/29/21 at 11:25 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date | |
|-----------------------|---------|-------|----|---------|-------|-----------|--------------|----------|
| Metals - Total | | | | | | | | |
| Copper (Cu) | 0.153 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA | 08/19/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA | 08/19/21 |

Approved By: Steve Distau

Approved On: 8/24/2021 9:01:45 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1507 JUNCTION
Sampled: 07/29/21 at 12:00 AM
Purpose: Routine
EPA Number: 0321

Sturgis
Sample Matrix: Water

Lab ID#: 20210729919
Received: 07/29/21 at 11:25 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|--------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.241 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/19/21 |
| Lead (Pb) | 0.002 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/19/21 |

Approved By: Steve Pistau

Approved On: 8/24/2021 9:01:45 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1751 ELLEN ST
Sampled: 07/27/21 at 04:00 AM
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Lab ID#: 20210803925
Received: 08/03/21 at 10:35 AM
by Steve Ristau
Account: 8392
Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|---------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.076 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/19/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/19/21 |

Approved By: Steve Ristau

Approved On: 8/24/2021 9:43:17 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 810 Shepard St.
Sampled: 08/05/21 at 07:00 AM
by Russell Abernathy
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

Lab ID#: 20210805917
Received: 08/05/21 at 11:23 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|--------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.103 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/19/21 |
| Lead (Pb) | 0.003 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/19/21 |

Approved By: Steve Ristan

Approved On: 8/24/2021 10:30:36 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1229 SPRUCE ST
Sampled: 07/20/21 at 06:50 AM
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

Lab ID#: 20210722911
Received: 07/22/21 at 08:57 AM
by Dean Aurand
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date | |
|-----------------------|--------|-------|----|---------|-------|-----------|--------------|----------|
| Metals - Total | | | | | | | | |
| Copper (Cu) | 0.113 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA | 08/12/21 |
| Lead (Pb) | 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA | 08/12/21 |

Notes:
Updated address per phone call with Russ.

Approved By: Steve Pistau

Approved On: 8/16/2021 11:19:43 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1814 DAVENPORT
Sampled: 07/20/21 at 04:18 AM
Purpose: Routine
EPA Number: 0321

Sample Matrix: Water Sturgis

Lab ID#: 20210722912
Received: 07/22/21 at 08:57 AM
by Dean Aurand
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|---------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.104 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/12/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/12/21 |

Approved By: Steve Pistau

Approved On: 8/16/2021 11:19:43 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 2120 BALDWIN ST
Sampled: 07/19/21 at 03:05 PM
Purpose: Routine
EPA Number: 0321

Sample Matrix: Water Sturgis

Lab ID#: 20210722913
Received: 07/22/21 at 08:57 AM
by Dean Aurand
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|---------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.123 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/12/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/12/21 |

Approved By: Steve Distau

Approved On: 8/16/2021 11:19:43 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 2326 S. Fulton
Sampled: 07/20/21 at 04:30 AM
Purpose: Routine
EPA Number: 0321

Sturgis
Sample Matrix: Water

Lab ID#: 20210722914
Received: 07/22/21 at 08:57 AM
by Dean Aurand
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|---------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.042 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/12/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/12/21 |

Approved By: Steve Distau

Approved On: 8/16/2021 11:19:43 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 515 MAIN ST
Sampled: 07/20/21 at 05:00 AM
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Lab ID#: 20210722915
Received: 07/22/21 at 08:57 AM
by Dean Aurand
Account: 8392
Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date | |
|-----------------------|--------|-------|----|---------|-------|-----------|--------------|----------|
| Metals - Total | | | | | | | | |
| Copper (Cu) | 0.067 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA | 08/12/21 |
| Lead (Pb) | 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA | 08/12/21 |

Approved By: Steve Pistau

Approved On: 8/16/2021 11:19:43 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1205 CEDAR DR
Sampled: 07/20/21 at 06:21 AM
Purpose: Routine
EPA Number: 0321

Sample Matrix: Water Sturgis

Lab ID#: 20210722910
Received: 07/22/21 at 08:57 AM
by Dean Aurand
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|--------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.125 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/12/21 |
| Lead (Pb) | 0.002 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/12/21 |

Approved By: Steve Ristau

Approved On: 8/16/2021 11:19:43 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 105 S AVE
Sampled: 07/20/21 at 06:00 AM
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Lab ID#: 20210722909
Received: 07/22/21 at 08:57 AM
by Dean Aurand
Account: 8392
Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|---------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.135 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/12/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/12/21 |

Approved By: Steve Ristan

Approved On: 8/16/2021 11:19:43 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 973 Howard
Sampled: 07/21/21 at 03:40 AM
Purpose: Routine
EPA Number: 0321

Sample Matrix: Water Sturgis

Lab ID#: 20210722908
Received: 07/22/21 at 08:57 AM
by Dean Aurand
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|--------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.185 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/12/21 |
| Lead (Pb) | 0.004 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/12/21 |

Approved By: Steve Ristau

Approved On: 8/16/2021 11:19:43 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 604 WEBER DR
Sampled: 07/21/21 at 06:25 AM
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Lab ID#: 20210722907
Received: 07/22/21 at 08:57 AM
by Dean Aurand
Account: 8392
Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|--------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.156 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/12/21 |
| Lead (Pb) | 0.002 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/12/21 |

Approved By: Steve Pistau

Approved On: 8/16/2021 11:19:43 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1502 JACKSON ST
Sampled: 07/22/21 at 12:00 AM
Purpose: Routine
EPA Number: 0321

Sample Matrix: Water Sturgis

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Lab ID#: 20210722906
Received: 07/22/21 at 08:57 AM
by Dean Aurand
Account: 8392
Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|---------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.097 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/12/21 |
| Lead (Pb) | < 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/12/21 |

Approved By: Steve Ristan

Approved On: 8/16/2021 11:19:43 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1006 McNENNY DR
Sampled: 07/21/21 at 08:08 AM
Purpose: Routine
EPA Number: 0321

Sample Matrix: Water Sturgis

Lab ID#: 20210722905
Received: 07/22/21 at 08:57 AM
by Dean Aurand
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------------|--------|-------|----|---------|-------|-----------|--------------|
| Metals - Total | | | | | | | |
| Copper (Cu) | 0.147 | mg/L | 10 | 0.00016 | 0.005 | EPA 200.8 | TNA 08/12/21 |
| Lead (Pb) | 0.001 | mg/L | 10 | 0.00019 | 0.001 | EPA 200.8 | TNA 08/12/21 |

Approved By: Steve Ristau

Approved On: 8/16/2021 11:19:43 AM



DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES

JOE FOSS BUILDING
523 E CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

August 12, 2021

Mr. Todd Youngberg

City of Sturgis

1057 Dudley St

Sturgis, SD 57785

SENT VIA EMAIL ONLY TO elainew@sturgisgov.com AND TYoungberg@sturgisgov.com

RE: VOC Sampling for Sturgis (EPA ID 0321)

Dear Mr. Youngberg:

The Drinking Water Program has received the test results of a drinking water compliance sample submitted for analysis of the Volatile Organic Chemicals(VOC's) from the City of Sturgis public water supply. The South Dakota Drinking Water Standards require that results of compliance monitoring be kept on file for not less than ten years.

Your system is required to monitor for these contaminants every three years for the entry point, Treat Site - Well #7. No regulated VOC's were detected in this water sample. The next triennial VOC sample for this entry point is due for analysis during 2024. VOC samples are taken at each entry point to the distribution system after treatment.

A summary of your test results is enclosed. If you have any questions concerning the test results or VOC monitoring requirements, please call me at 605 773-6576.

Sincerely,

Mitchel Williams

Drinking Water Program

cy: Elaine Wolken, Finance Officer

Regulated Volatile Organic Chemical (VOC) Data

System: City of Sturgis
 Entry Point: O32123 Treat Site - Well #7
 Facility: O321 Sturgis
 Monitoring Status: Triennially

Definitions: ND - Not Detected
 ug/l - microgram per liter

| Chemical | Date | Value (ug/l) |
|----------------------------|------------|--------------|
| 1,1-Dichloroethylene | 04/21/2021 | ND |
| 1,1,1-Trichloroethane | 04/21/2021 | ND |
| 1,1,2-Trichloroethane | 04/21/2021 | ND |
| 1,2-Dichloroethane | 04/21/2021 | ND |
| 1,2,4-Trichlorobenzene | 04/21/2021 | ND |
| 1,2-Dichloropropane | 04/21/2021 | ND |
| Benzene | 04/21/2021 | ND |
| Carbon Tetrachloride | 04/21/2021 | ND |
| Chlorobenzene | 04/21/2021 | ND |
| Dichloromethane | 04/21/2021 | ND |
| Ethylbenzene | 04/21/2021 | ND |
| Styrene | 04/21/2021 | ND |
| Tetrachloroethylene | 04/21/2021 | ND |
| Toluene | 04/21/2021 | ND |
| Trichloroethylene | 04/21/2021 | ND |
| Vinyl Chloride | 04/21/2021 | ND |
| cis-1,2-Dichloroethylene | 04/21/2021 | ND |
| m-Xylene | 04/21/2021 | ND |
| o-Dichlorobenzene | 04/21/2021 | ND |
| o-Xylene | 04/21/2021 | ND |
| p-Xylene | 04/21/2021 | ND |
| para-Dichlorobenzene | 04/21/2021 | ND |
| trans-1,2-Dichloroethylene | 04/21/2021 | ND |



DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES

JOE FOSS BUILDING
523 E CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

August 17, 2021

Mr. Todd Youngberg
City of Sturgis
1057 Dudley St
Sturgis, SD 57785

SENT VIA EMAIL ONLY TO elainew@sturgisgov.com AND TYoungberg@sturgisgov.com

RE: SOC Sampling for Sturgis (EPA ID 0321)

Dear Mr. Youngberg:

The Drinking Water Program has received the test results of a drinking water compliance sample submitted for analysis of the Synthetic Organic Chemicals (SOC's) from the City of Sturgis for the Treat Site - Well #7 entry point. No regulated SOC's were detected in this sample.

Synthetic Organic Chemicals are divided into seven groups for compliance and waiver purposes. Each of these groups can have a separate sampling requirement depending on your waivers and past sampling history. The SOC sampling status for this entry point is as follows:

Entry Point: 23 Treat Site - Well #7

| Group | Sampled Last | Current Status | Sampling Requirements |
|-------|--------------|-------------------------------------|---|
| 549 | 04/21/2021 | Triennial Monitoring - 50% Complete | A Sample Due In The Third Quarter Of 2021 |
| 548 | 04/21/2021 | Triennial Monitoring - 50% Complete | A Sample Due In The Third Quarter Of 2021 |
| 547 | 04/21/2021 | Triennial Monitoring - 50% Complete | A Sample Due In The Third Quarter Of 2021 |
| 531 | 04/21/2021 | Triennial Monitoring - 50% Complete | A Sample Due In The Third Quarter Of 2021 |
| 525 | 04/21/2021 | Triennial Monitoring - 50% Complete | A Sample Due In The Third Quarter Of 2021 |
| 515 | 04/21/2021 | Triennial Monitoring - 50% Complete | A Sample Due In The Third Quarter Of 2021 |
| 504 | 04/21/2021 | Triennial Monitoring - 50% Complete | A Sample Due In The Third Quarter Of 2021 |

If you have any questions concerning the test results or SOC monitoring requirements, please call me at 605 773-6576.

Sincerely,

Mitchel Williams
Drinking Water Program

cy: Elaine Wolken, Financial Contact



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis (#3)
Sampled: 05/12/21 at 08:43 AM
by Erin Fagnan
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

ERIN FAGNAN
DENR
2050 WEST MAIN ST STE #1
RAPID CITY, SD 57702

Lab ID#: 20210512937
Received: 05/12/21 at 12:00 PM
by System Account
Account: 8591
DENR - Drinking Water Program

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------------|---------|----------|-------|---------|-------|---------------|--------------|
| Physical Properties | | | | | | | |
| Electrical Conductivity | 483 | µmhos/cm | 1 | 0.153 | 5.00 | SM 2510B | JAM 05/13/21 |
| 14.43 Hardness | 244 | mg/L | 1 | | | SM 2340 B | SCR 05/18/21 |
| 7.41/5 pH | 8.03 | S.U. | 1 | | | SM 4500-H+ B | JAM 05/13/21 |
| Total Dissolved Solids | 278 | mg/L | 100ml | 13.0 | 50.0 | SM 2540 C | TMN 05/13/21 |
| Non-Metallics | | | | | | | |
| Alkalinity (CaCO3) | 196 | mg/L | 1 | 0.226 | 10.0 | SM 2320 B | JAM 05/13/21 |
| Bicarbonate | 239 | mg/L | 1 | 0.276 | 10.0 | SM 2320 B | JAM 05/13/21 |
| Chloride (Cl-) | 4.82 | mg/L | 1 | 0.186 | 0.500 | SM 4500-Cl E | BLL 05/14/21 |
| Fluoride | 0.217 | mg/L | 1 | 0.008 | 0.015 | SM 4500 F-C | TMN 05/13/21 |
| Langelier Scale Index | 0.622 | LSI | 1 | | | Calculation | SCR 05/18/21 |
| Nitrogen, Nitrate (NO3) | 0.402 | mg/L | 1 | 0.008 | 0.050 | SM 4500-NO3 F | BLL 05/13/21 |
| Nitrogen, Nitrite (NO2) | < 0.050 | mg/L | 1 | 0.005 | 0.050 | SM 4500-NO2 B | BLL 05/13/21 |
| Sulfate (SO4) | 58.8 | mg/L | 1 | 0.483 | 10.0 | SM 4500-SO4 E | BLL 05/14/21 |
| Metals - Dissolved | | | | | | | |
| Calcium (Ca) | 63.4 | mg/L | 2 | 0.140 | 2.00 | SM 3111 B | TMS 05/17/21 |
| Magnesium (Mg) | 20.7 | mg/L | 1 | 0.036 | 0.500 | SM 3111 B | TMS 05/17/21 |
| Potassium (K) | 1.71 | mg/L | 1 | 0.040 | 0.500 | SM 3111 B | TMS 05/17/21 |
| Sodium (Na) | 5.29 | mg/L | 1 | 0.020 | 0.500 | SM 3111 B | TMS 05/17/21 |
| Metals - Total | | | | | | | |
| Iron (Fe) | < 0.050 | mg/L | 10 | 0.00093 | 0.050 | EPA 200.8 | TNA 05/14/21 |
| Manganese (Mn) | < 0.010 | mg/L | 10 | 0.00006 | 0.010 | EPA 200.8 | TNA 05/14/21 |

Approved By: Steve Distau

Approved On: 5/18/2021 1:21:40 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis (#7)
Sampled: 05/12/21 at 09:28 AM
by Erin Fagnan
Purpose: Survey
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20210512938
Received: 05/12/21 at 12:00 PM
by System Account
Account: 8591
DENR - Drinking Water Program

ERIN FAGNAN
DENR
2050 WEST MAIN ST STE #1
RAPID CITY, SD 57702

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------------|---------|----------|-------|---------|-------|---------------|--------------|
| Physical Properties | | | | | | | |
| Electrical Conductivity | 486 | µmhos/cm | 1 | 0.153 | 5.00 | SM 2510B | JAM 05/13/21 |
| Hardness | 247 | mg/L | 1 | | | SM 2340 B | SCR 05/18/21 |
| pH | 7.90 | S.U. | 1 | | | SM 4500-H+ B | JAM 05/13/21 |
| Total Dissolved Solids | 290 | mg/L | 100ml | 13.0 | 50.0 | SM 2540 C | TMN 05/13/21 |
| Non-Metallics | | | | | | | |
| Alkalinity (CaCO3) | 189 | mg/L | 1 | 0.226 | 10.0 | SM 2320 B | JAM 05/13/21 |
| Bicarbonate | 230 | mg/L | 1 | 0.276 | 10.0 | SM 2320 B | JAM 05/13/21 |
| Chloride (Cl-) | 6.97 | mg/L | 1 | 0.186 | 0.500 | SM 4500-Cl E | BLL 05/14/21 |
| Fluoride | 0.553 | mg/L | 1 | 0.008 | 0.015 | SM 4500 F-C | TMN 05/13/21 |
| Langelier Scale Index | 0.486 | LSI | 1 | | | Calculation | SCR 05/18/21 |
| Sulfate (SO4) | 64.8 | mg/L | 1 | 0.483 | 10.0 | SM 4500-SO4 E | BLL 05/14/21 |
| Metals - Dissolved | | | | | | | |
| Calcium (Ca) | 64.8 | mg/L | 3 | 0.210 | 3.00 | SM 3111 B | TMS 05/17/21 |
| Magnesium (Mg) | 20.6 | mg/L | 1 | 0.036 | 0.500 | SM 3111 B | TMS 05/17/21 |
| Potassium (K) | 1.78 | mg/L | 1 | 0.040 | 0.500 | SM 3111 B | TMS 05/17/21 |
| Sodium (Na) | 5.98 | mg/L | 1 | 0.020 | 0.500 | SM 3111 B | TMS 05/17/21 |
| Metals - Total | | | | | | | |
| Iron (Fe) | < 0.050 | mg/L | 10 | 0.00093 | 0.050 | EPA 200.8 | TNA 05/14/21 |
| Manganese (Mn) | < 0.010 | mg/L | 10 | 0.00006 | 0.010 | EPA 200.8 | TNA 05/14/21 |

Approved By: Steve Distau

Approved On: 5/18/2021 1:21:40 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: WELL #7
Sampled: 04/21/21 at 09:30 AM
by Todd Youngberg
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20210421908
Received: 04/21/21 at 10:30 AM
by Tanya Nelsen

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|------------------------------|---------|-------|----|-------|-------|----------------------------|--------------|
| <u>Volatile</u> | | | | | | | |
| Benzene | < 0.500 | µg/L | 1 | 0.059 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Carbon Tetrachloride | < 0.500 | µg/L | 1 | 0.072 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Chlorobenzene | < 0.500 | µg/L | 1 | 0.072 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| 1,2-Dichloroethane | < 0.500 | µg/L | 1 | 0.051 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| 1,2-Dichlorobenzene | < 0.500 | µg/L | 1 | 0.065 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| 1,4-Dichlorobenzene | < 0.500 | µg/L | 1 | 0.064 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| 1,1-Dichloroethylene | < 0.500 | µg/L | 1 | 0.076 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Cis-1,2-Dichloroethylene | < 0.500 | µg/L | 1 | 0.067 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Trans-1,2-Dichloroethylene | < 0.500 | µg/L | 1 | 0.059 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Dichloromethane | < 0.500 | µg/L | 1 | 0.041 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| 1,2-Dichloropropane | < 0.500 | µg/L | 1 | 0.052 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Ethylbenzene | < 0.500 | µg/L | 1 | 0.088 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Styrene | < 0.500 | µg/L | 1 | 0.063 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Tetrachloroethylene | < 0.500 | µg/L | 1 | 0.082 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Toluene | < 0.500 | µg/L | 1 | 0.078 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| 1,1,1-Trichloroethane | < 0.500 | µg/L | 1 | 0.078 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| 1,1,2-Trichloroethane | < 0.500 | µg/L | 1 | 0.066 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| 1,2,4-Trichlorobenzene | < 0.500 | µg/L | 1 | 0.070 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Trichloroethylene | < 0.500 | µg/L | 1 | 0.075 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Vinyl Chloride | < 0.500 | µg/L | 1 | 0.053 | 0.500 | EPA 524.2 | RAM 04/24/21 |
| Xylenes(o,m,p) | < 1.00 | µg/L | 1 | 0.065 | 1.00 | EPA 524.2 | RAM 04/24/21 |
| <u>Radiological</u> | | | | | | | |
| Gross Alpha | 1.42 | pCi/L | 1 | | | EPA 900.0 | EJF 06/07/21 |
| Radium-226 | 0.410 | pCi/L | 1 | | | MC Radium-226 | EJF 06/16/21 |
| Radium-228 | 0.463 | pCi/L | 1 | | | MC Radium-228 | EJF 06/16/21 |
| <u>Precision Data</u> | | | | | | | |
| Gross Alpha precision | ± 0.520 | pCi/L | 1 | | | MC - Gross Alpha precision | EJF 06/07/21 |
| Radium-226 precision | ± 0.182 | pCi/L | 1 | | | MC-Radium 226 precision | EJF 06/16/21 |
| Radium-228 precision | ± 0.199 | pCi/L | 1 | | | MC-Radium 228 precision | EJF 06/16/21 |

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-----------------|--------|-------|----|-----|-----|----------------------|--------------|
| MDA Data | | | | | | | |
| Gross Alpha MDA | 1.63 | pCi/L | 1 | | | MC - Gross Alpha MDA | EJF 06/04/21 |
| Radium-226 MDA | 0.370 | pCi/L | 1 | | | MC - Radium 226 MDA | EJF 06/16/21 |
| Radium-228 MDA | 0.419 | pCi/L | 1 | | | MC - Radium 228 MDA | EJF 06/16/21 |

Approved By: Steve Distau

Approved On: 7/6/2021 2:02:15 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: WELL #7
 Sampled: 07/13/21 at 07:11 AM
 by Brant Ager
 Purpose: Routine
 EPA Number: 0321
 Sturgis
 Sample Matrix: Water
 Lab ID#: 20210712609
 Received: 07/13/21 at 09:25 AM
 by Sarah Ahlers
 Account: 8392
 Sturgis Water Company

RICK BUSH
 STURGIS WATER COMPANY
 1040 HARLEY-DAVIDSON WAY
 STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|--|---------|-------|----|-----|-----|-----------|--------------|
| <u>SOC Organohalide Pesticides + PCBs</u> | | | | | | | |
| Alachlor | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Aldrin | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Aroclor 1016 | < 0.080 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Aroclor 1221 | < 0.500 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Aroclor 1232 | < 0.500 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Aroclor 1242 | < 0.300 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Aroclor 1248 | < 0.100 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Aroclor 1254 | < 0.100 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Aroclor 1260 | < 0.200 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Chlordane | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Dieldrin | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Endrin | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Heptachlor | < 0.400 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Heptachlor Epoxide | < 0.200 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Hexachlorobenzene | < 0.500 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Hexachlorocyclopentadiene | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Lindane | < 0.200 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Methoxychlor | < 2.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Toxaphene | < 2.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| <u>SOC Organic Chemicals</u> | | | | | | | |
| Atrazine | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Benzo (a) pyrene | < 0.200 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Butachlor | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Bis (2-ethylhexyl) Adipate | < 3.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Bis (2-ethylhexyl) Phthalate | < 3.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Metolachlor | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Metribuzin | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| Propachlor | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |

| <u>Parameter</u> | <u>Result</u> | <u>Units</u> | <u>DF</u> | <u>MDL</u> | <u>PQL</u> | <u>Method</u> | <u>Analyst/Date</u> |
|--------------------------------------|---------------|--------------|-----------|------------|------------|---------------|---------------------|
| <u>SOC Organic Chemicals</u> | | | | | | | |
| Simazine | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 07/30/21 |
| <u>Semi-Volatile</u> | | | | | | | |
| DBCP | < 0.050 | µg/L | 1 | | | EPA 504.1 | SAC 07/22/21 |
| Ethylene Dibromide(EDB) | < 0.050 | µg/L | 1 | | | EPA 504.1 | SAC 07/22/21 |
| <u>SOC Carbamates</u> | | | | | | | |
| 3-Hydroxycarbofuran | < 4.00 | µg/L | 1 | 0.377 | 4.00 | EPA 531.1 | EJF 07/16/21 |
| Aldicarb | < 1.00 | µg/L | 1 | 0.398 | 1.00 | EPA 531.1 | EJF 07/16/21 |
| Aldicarb Sulfone | < 1.00 | µg/L | 1 | 0.333 | 1.00 | EPA 531.1 | EJF 07/16/21 |
| Aldicarb Sulfoxide | < 1.00 | µg/L | 1 | 0.351 | 1.00 | EPA 531.1 | EJF 07/16/21 |
| Carbaryl | < 4.00 | µg/L | 1 | 0.385 | 4.00 | EPA 531.1 | EJF 07/16/21 |
| Carbofuran | < 4.00 | µg/L | 1 | 0.457 | 4.00 | EPA 531.1 | EJF 07/16/21 |
| Methomyl | < 4.00 | µg/L | 1 | 0.387 | 4.00 | EPA 531.1 | EJF 07/16/21 |
| Oxamyl | < 2.00 | µg/L | 1 | 0.407 | 2.00 | EPA 531.1 | EJF 07/16/21 |
| <u>SOC Diquat</u> | | | | | | | |
| Diquat Dibromide | < 4.00 | µg/L | 1 | | | EPA 549.2 | EJF 07/21/21 |
| <u>SOC Endothall</u> | | | | | | | |
| Endothall | < 8.00 | µg/L | 1 | | | EPA 548.1 | SYS 07/26/21 |
| <u>SOC Glyphosate</u> | | | | | | | |
| Glyphosate | < 50.0 | µg/L | 1 | 3.58 | 50.0 | EPA 547 | EJF 07/22/21 |
| <u>OC Chlorinated Acids</u> | | | | | | | |
| 2,4,5-Trichlorophenoxypropionic acid | < 1.00 | µg/L | 1 | 0.197 | 1.00 | EPA 515.3 | SAC 07/28/21 |
| 2,4-Dichlorophenoxyacetic acid | < 8.00 | µg/L | 1 | 0.391 | 8.00 | EPA 515.3 | SAC 07/28/21 |
| Dalapon | < 10.0 | µg/L | 1 | 0.330 | 10.0 | EPA 515.3 | SAC 07/28/21 |
| Dicamba | < 4.00 | µg/L | 1 | 0.245 | 4.00 | EPA 515.3 | SAC 07/28/21 |
| Dinoseb | < 1.00 | µg/L | 1 | 0.142 | 1.00 | EPA 515.3 | SAC 07/28/21 |
| Pentachlorophenol | < 0.500 | µg/L | 1 | 0.118 | 0.500 | EPA 515.3 | SAC 07/28/21 |
| Picloram | < 4.00 | µg/L | 1 | 0.179 | 4.00 | EPA 515.3 | SAC 07/28/21 |

Notes:

Endothall analysis performed by Energy Laboratories.

Approved By: Steve Ristau

Approved On: 8/16/2021 3:19:42 PM



DEPARTMENT of AGRICULTURE
and NATURAL RESOURCES

JOE FOSS BUILDING
523 E CAPITOL AVE
PIERRE SD 57501-3182
danr.sd.gov

November 03, 2021

Mr. Todd Youngberg
City of Sturgis
1057 Dudley St
Sturgis, SD 57785

SENT VIA EMAIL ONLY TO elainew@sturgisgov.com AND TYoungberg@sturgisgov.com

RE: SOC Sampling for Sturgis (EPA ID 0321)

Dear Mr. Youngberg:

The Drinking Water Program has received the test results of a drinking water compliance sample submitted for analysis of the Synthetic Organic Chemicals (SOC's) from the City of Sturgis for the Treat Site - Well #7 entry point. No regulated SOC's were detected in this sample.

Synthetic Organic Chemicals are divided into seven groups for compliance and waiver purposes. Each of these groups can have a separate sampling requirement depending on your waivers and past sampling history. The SOC sampling status for this entry point is as follows:

Entry Point: 23 Treat Site - Well #7

| Group | Sampled Last | Current Status | Sampling Requirements |
|-------|--------------|----------------------|---|
| 549 | 07/13/2021 | Triennial Monitoring | Two Consecutive Quarterly Samples Due In 2024 |
| 548 | 07/13/2021 | Triennial Monitoring | Two Consecutive Quarterly Samples Due In 2024 |
| 547 | 07/13/2021 | Triennial Monitoring | Two Consecutive Quarterly Samples Due In 2024 |
| 531 | 07/13/2021 | Triennial Monitoring | Two Consecutive Quarterly Samples Due In 2024 |
| 525 | 07/13/2021 | Triennial Monitoring | Two Consecutive Quarterly Samples Due In 2024 |
| 515 | 07/13/2021 | Triennial Monitoring | Two Consecutive Quarterly Samples Due In 2024 |
| 504 | 07/13/2021 | Triennial Monitoring | Two Consecutive Quarterly Samples Due In 2024 |

If you have any questions concerning the test results or SOC monitoring requirements, please call me at 605 773-6576.

Sincerely,

Sammi Blood
Drinking Water Program

cy: Elaine Wolken, Financial Contact



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: WELL #7
Sampled: 04/21/21 at 09:30 AM
by Todd Youngberg
Purpose: Routine
EPA Number: 0321
Sturgis

Sample Matrix: Water

Lab ID#: 20210420639
Received: 04/21/21 at 10:30 AM
by Tanya Nelsen
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|--|---------|-------|----|-------|-------|-----------|--------------|
| <u>SOC Organohalide Pesticides + PCBs</u> | | | | | | | |
| Alachlor | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Aldrin | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Aroclor 1016 | < 0.080 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Aroclor 1221 | < 0.500 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Aroclor 1232 | < 0.500 | µg/L | 1 | 0.053 | 0.500 | EPA 525.2 | RAM 05/13/21 |
| Aroclor 1242 | < 0.300 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Aroclor 1248 | < 0.100 | µg/L | 1 | 0.051 | 0.100 | EPA 525.2 | RAM 05/13/21 |
| Aroclor 1254 | < 0.100 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Aroclor 1260 | < 0.200 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Chlordane | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Dieldrin | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Endrin | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Heptachlor | < 0.400 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Heptachlor Epoxide | < 0.200 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Hexachlorobenzene | < 0.500 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Hexachlorocyclopentadiene | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Lindane | < 0.200 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Methoxychlor | < 2.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Toxaphene | < 2.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| <u>SOC Organic Chemicals</u> | | | | | | | |
| Atrazine | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Benzo (a) pyrene | < 0.200 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Butachlor | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Bis (2-ethylhexyl) Adipate | < 3.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Bis (2-ethylhexyl) Phthalate | < 3.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Metolachlor | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Metribuzin | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| Propachlor | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|--------------------------------------|---------|-------|----|-------|-------|-----------|--------------|
| <u>SOC Organic Chemicals</u> | | | | | | | |
| Simazine | < 1.00 | µg/L | 1 | | | EPA 525.2 | RAM 05/13/21 |
| <u>Semi-Volatile</u> | | | | | | | |
| DBCP | < 0.050 | µg/L | 1 | 0.031 | 0.050 | EPA 504.1 | SAC 04/30/21 |
| Ethylene Dibromide(EDB) | < 0.050 | µg/L | 1 | 0.017 | 0.050 | EPA 504.1 | SAC 04/30/21 |
| <u>SOC Carbamates</u> | | | | | | | |
| 3-Hydroxycarbofuran | < 4.00 | µg/L | 1 | 0.377 | 4.00 | EPA 531.1 | EJF 05/05/21 |
| Aldicarb | < 1.00 | µg/L | 1 | 0.398 | 1.00 | EPA 531.1 | EJF 05/05/21 |
| Aldicarb Sulfone | < 1.00 | µg/L | 1 | 0.333 | 1.00 | EPA 531.1 | EJF 05/05/21 |
| Aldicarb Sulfoxide | < 1.00 | µg/L | 1 | 0.351 | 1.00 | EPA 531.1 | EJF 05/05/21 |
| Carbaryl | < 4.00 | µg/L | 1 | 0.385 | 4.00 | EPA 531.1 | EJF 05/05/21 |
| Carbofuran | < 4.00 | µg/L | 1 | 0.457 | 4.00 | EPA 531.1 | EJF 05/05/21 |
| Methomyl | < 4.00 | µg/L | 1 | 0.387 | 4.00 | EPA 531.1 | EJF 05/05/21 |
| Oxamyl | < 2.00 | µg/L | 1 | 0.407 | 2.00 | EPA 531.1 | EJF 05/05/21 |
| <u>SOC Diquat</u> | | | | | | | |
| Diquat Dibromide | < 4.00 | µg/L | 1 | 0.362 | 4.00 | EPA 549.2 | EJF 04/27/21 |
| <u>SOC Endothall</u> | | | | | | | |
| Endothall | < 8.00 | µg/L | 1 | | | EPA 548.1 | SYS 04/27/21 |
| <u>SOC Glyphosate</u> | | | | | | | |
| Glyphosate | < 50.0 | µg/L | 1 | 3.58 | 50.0 | EPA 547 | EJF 04/30/21 |
| <u>DC Chlorinated Acids</u> | | | | | | | |
| 2,4,5-Trichlorophenoxypropionic acid | < 1.00 | µg/L | 1 | 0.197 | 1.00 | EPA 515.3 | SAC 05/06/21 |
| 2,4-Dichlorophenoxyacetic acid | < 8.00 | µg/L | 1 | 0.391 | 8.00 | EPA 515.3 | SAC 05/06/21 |
| Dalapon | < 10.0 | µg/L | 1 | 0.330 | 10.0 | EPA 515.3 | SAC 05/06/21 |
| Dicamba | < 4.00 | µg/L | 1 | 0.245 | 4.00 | EPA 515.3 | SAC 05/06/21 |
| Dinoseb | < 1.00 | µg/L | 1 | 0.142 | 1.00 | EPA 515.3 | SAC 05/06/21 |
| Pentachlorophenol | < 0.500 | µg/L | 1 | 0.118 | 0.500 | EPA 515.3 | SAC 05/06/21 |
| Picloram | < 4.00 | µg/L | 1 | 0.179 | 4.00 | EPA 515.3 | SAC 05/06/21 |

Notes:

Endothall analysis performed by Energy Laboratories.

Approved By: Steve Pistau

Approved On: 6/1/2021 2:13:45 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: WELL #7
Sampled: 04/21/21 at 09:30 AM
by Todd Youngberg
Purpose: Routine
EPA Number: 0321
Sturgis

Sample Matrix: Water

Lab ID#: 20210421907
Received: 04/21/21 at 10:30 AM
by Tanya Nelsen
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|-------------------------|----------|-------|----|---------|--------|---------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.647 | mg/L | 1 | 0.008 | 0.015 | SM 4500 F-C | TMN 04/23/21 |
| Nitrogen, Nitrate (NO3) | 0.645 | mg/L | 10 | 0.079 | 0.500 | SM 4500-NO3 F | BLL 04/22/21 |
| Metals - Total | | | | | | | |
| Antimony (Sb) | < 0.005 | mg/L | 10 | 0.00028 | 0.005 | EPA 200.8 | TNA 04/23/21 |
| Arsenic (As) | < 0.005 | mg/L | 10 | 0.00061 | 0.005 | EPA 200.8 | TNA 04/23/21 |
| Barium (Ba) | 0.125 | mg/L | 10 | 0.00014 | 0.005 | EPA 200.8 | TNA 04/23/21 |
| Beryllium (Be) | < 0.001 | mg/L | 10 | 0.00004 | 0.001 | EPA 200.8 | TNA 04/23/21 |
| Cadmium (Cd) | < 0.001 | mg/L | 10 | 0.00024 | 0.001 | EPA 200.8 | TNA 04/23/21 |
| Chromium (Cr) | < 0.001 | mg/L | 10 | 0.00012 | 0.001 | EPA 200.8 DRC | TNA 04/23/21 |
| Mercury (Hg) | < 0.0002 | mg/L | 1 | 0.00005 | 0.0002 | EPA 245.1 | TMS 04/23/21 |
| Nickel (Ni) | < 0.005 | mg/L | 10 | 0.00008 | 0.005 | EPA 200.8 | TNA 04/23/21 |
| Selenium (Se) | < 0.005 | mg/L | 10 | 0.00077 | 0.005 | EPA 200.8 | TNA 04/23/21 |
| Thallium (Tl) | < 0.001 | mg/L | 10 | 0.00003 | 0.001 | EPA 200.8 | TNA 04/23/21 |

Approved By: Steve Ristau

Approved On: 4/27/2021 1:58:26 PM



MIDCONTINENT

TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 06/17/21 at 09:20 AM
by Avery Samuel

Account: 9947
Wilson Contracting, LLC

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

DRINKING WATER REPORT

| EPA # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | NITRATE | ANALYST | LAB NUMBER |
|-------|---------------------|--------------|--------------------|-----------------------------------|----------------------------|---------|----------------|-------------|
| | FH @ Vanocker Rd. 1 | | 06/17/21 08:45 AM | Absent | Absent | | JMH 06/17/2021 | 20210617808 |

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

6/18/2021 12:44:12 PM

DATE PRINTED:

06/23/2021 09:06 AM



MIDCONTINENT

TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 06/18/21 at 09:05 AM
by Jennifer Hill
Account: 9947
Wilson Contracting, LLC

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

DRINKING WATER REPORT

| EPA # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | NITRATE | ANALYST | LAB NUMBER |
|-------|---------------------|--------------|--------------------|-----------------------------------|----------------------------|---------|----------------|-------------|
| | FH @ Vanocker Rd. 1 | | 06/18/21 08:35 AM | Absent | Absent | | JMH 06/18/2021 | 20210618810 |

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

6/21/2021 1:07:45 PM

DATE PRINTED:

06/23/2021 09:06 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: FH at end of Joseph Ct.
Sampled: 05/18/21 at 07:45 AM
Sample Matrix: Water

Lab ID#: 20210518808
Received: 05/18/21 at 09:15 AM
by Avery Samuel
Account: 9947 - Wilson Contracting, LLC

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

| Parameter | Result | Units | DF | Method | Analyst/Date | |
|-----------------|--------|-------|----|-----------------|--------------|----------|
| Bacteria | | | | | | |
| E. coli | Absent | | 1 | SM 9223 B (P/A) | JMH | 05/18/21 |
| Total Coliform | Absent | | 1 | SM 9223 B (P/A) | JMH | 05/18/21 |

Report Approved By:

Steve Pistau

Report Approved On: 5/19/2021 1:58:18 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: FH at end of Joseph Ct.
Sampled: 05/19/21 at 08:30 AM
Sample Matrix: Water

Lab ID#: 20210519807
Received: 05/19/21 at 09:45 AM
by Jennifer Hill
Account: 9947 - Wilson Contracting, LLC

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

| Parameter | Result | Units | DF | Method | Analyst/Date |
|-----------------|--------|-------|----|-----------------|--------------|
| Bacteria | | | | | |
| E. coli | Absent | | 1 | SM 9223 B (P/A) | JMH 05/19/21 |
| Total Coliform | Absent | | 1 | SM 9223 B (P/A) | JMH 05/19/21 |

Report Approved By:

Steve Distau

Report Approved On: 5/20/2021 2:49:15 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 04/13/21 at 09:00 AM
by System Account
Account: 9947
Wilson Contracting, LLC

Davenport

DOUG WILSON
WILSON CONTRACTING, LLC
21652 PIEDMONT MEADOWS
PIEDMONT, SD 57769

DRINKING WATER REPORT

| EPA # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | NITRATE | ANALYST | LAB NUMBER |
|-------|--------------|---------------|--------------------|--------------------------------|-------------------------|---------|----------------|-------------|
| | Jarvis Ct. 1 | South hydrant | 04/13/21 08:00 AM | Absent | Absent | | SAA 04/13/2021 | 20210413808 |

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: *Jennifer Hill*

REPORT APPROVED DATE: 4/14/2021 4:35:30 PM

DATE PRINTED: 04/14/2021 04:36 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

81 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Received: 03/09/21 at 12:00 PM
by System Account
Account: 9465
Rapid Construction

Trailhead

WAYNE MAY
RAPID CONSTRUCTION
2783 PLANT ST.
RAPID CITY, SD 57702

DRINKING WATER REPORT

| EPA # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | NITRATE | ANALYST | LAB NUMBER |
|-------|-------------|--------------|--------------------|--------------------------------|-------------------------|---------|----------------|-------------|
| | FH #11 | | 03/09/21 10:08 AM | Absent | Absent | | JMH 03/09/2021 | 20210309853 |

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

3/10/2021 12:45:51 PM

DATE PRINTED:

03/10/2021 12:50 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

281 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Trailhead

Received: 03/08/21 at 12:30 PM
by Jennifer Hill
Account: 9465
Rapid Construction

CASY OR JOE
AE2S
1560 CONCOURSE DR
RAPID CITY, SD 57703

DRINKING WATER REPORT

| EPA # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | NITRATE | ANALYST | LAB NUMBER |
|-------|-----------------------|--------------|--------------------|--------------------------------|-------------------------|---------|----------------|-------------|
| | FH North ₁ | | 03/08/21 10:20 AM | Absent | Absent | | JMH 03/08/2021 | 20210308820 |

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/9/2021 2:10:44 PM

DATE PRINTED: 03/09/2021 02:16 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Parks Dept. Shop (1920 Ballpark A)
Sampled: 12/07/21 at 07:35 AM by Russ
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20211207882
Received: 12/07/21 at 12:00 PM by Jennifer Hill
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.592 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 12/09/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.550 | mg/L | 1 | | | Field Fluoride | SYS 12/08/21 |

Approved By: Steve Distau

Approved On: 12/9/2021 3:33:15 PM



2281 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Rasmussen Mech. Services
(3590 Mayor Ave)
Sampled: 12/02/21 at 07:09 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20211202842
Received: 12/02/21 at 10:15 AM
by Jennifer Hill
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 1.34 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 12/07/21 |
| Field Test | | | | | | | |
| Field Fluoride | 1.47 | mg/L | 1 | | | Field Fluoride | JMH 12/03/21 |

Approved By: Steve Distau

Approved On: 12/7/2021 1:00:13 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Scott Peterson Motors
Sampled: 11/15/21 at 07:30 AM
by Russ
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20211115826
Received: 11/15/21 at 10:23 AM
by Eric Fuehrer

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.654 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 11/17/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.810 | mg/L | 1 | | | Field Fluoride | SYS 11/15/21 |

Approved By: Steve Pistau

Approved On: 11/18/2021 10:56:07 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Butte Ridge Building E (1900 Ellen St.)
Sampled: 11/08/21 at 08:58 AM by W. Hix
Purpose: Routine
EPA Number: 0321
Sample Matrix: Water
Lab ID#: 20211108853
Received: 11/08/21 at 02:55 PM by Sarah Ahlers
Account: 8392

Sturgis

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 1.42 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 11/10/21 |
| Field Test | | | | | | | |
| Field Fluoride | 1.66 | mg/L | 1 | | | Field Fluoride | SYS 11/09/21 |

Approved By: Steve Pistau

Approved On: 11/10/2021 2:19:36 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Pete Lien & Sons (2025 Sherman)
Sampled: 10/21/21 at 06:38 AM
by Brant
Purpose: Routine
EPA Number: 0321

Sturgis

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Matrix: Water

Lab ID#: 20211021820
Received: 10/21/21 at 09:40 AM
by Sarah Ahlers
Account: 8392

Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 1.28 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 10/26/21 |
| Field Test | | | | | | | |
| Field Fluoride | 1.45 | mg/L | 1 | | | Field Fluoride | SYS 10/22/21 |

Approved By: Steve Distau

Approved On: 10/26/2021 3:40:31 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Parks Dept. Shop (1920 Ballpark A)
Sampled: 10/12/21 at 07:45 AM by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20211012837
Received: 10/12/21 at 11:07 AM by Eric Fuehrer
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.806 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 10/13/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.940 | mg/L | 1 | | | Field Fluoride | JMH 10/13/21 |

Approved By: Steve Pistau

Approved On: 10/13/2021 4:26:39 PM



MIDCONTINENT

TESTING LABORATORIES, INC.

381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)
Sampled: 09/20/21 at 07:45 AM
by Russ
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20210920861
Received: 09/20/21 at 11:30 AM
by Jennifer Hill
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.730 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 09/21/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.980 | mg/L | 1 | | | Field Fluoride | SYS 09/21/21 |

Approved By: Steve Pistau

Approved On: 9/21/2021 3:50:44 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis City Hall (1040 Harley-Davidson Way)
Sampled: 09/14/21 at 07:38 AM
by Wyatt Hix
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20210914876
Received: 09/14/21 at 09:30 AM
by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.816 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 09/15/21 |
| Field Test | | | | | | | |
| Field Fluoride | 1.00 | mg/L | 1 | | | Field Fluoride | JMH 09/15/21 |

Approved By: Steve Pistau

Approved On: 9/16/2021 9:31:38 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Pete Lien & Sons (2025 Sherman)
Sampled: 08/18/21 at 06:31 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321
Sample Matrix: Water
Lab ID#: 20210818838
Received: 08/18/21 at 09:35 AM
by Sarah Ahlers
Account: 8392

Sturgis

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 1.11 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 08/25/21 |
| Field Test | | | | | | | |
| Field Fluoride | 1.30 | mg/L | 1 | | | Field Fluoride | JMH 08/19/21 |

Approved By: Steve Pistau

Approved On: 8/25/2021 10:40:13 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Heritage Acres Building
 Purpose: Routine
 EPA Number: 0321
 Sampled: 08/05/21 at 08:13 AM by Wyatt Hix
 Sample Matrix: Water
 Lab ID#: 20210805840
 Received: 08/05/21 at 11:23 AM by Jennifer Hill
 Account: 8392 - Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.814 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 08/06/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.960 | mg/L | 1 | | | Field Fluoride | JMH 08/06/21 |

Report Approved By: Jennifer Hill

Report Approved On: 8/9/2021 9:37:16 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 17
Sampled: 07/13/21 at 08:50 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321
Sturgis

Sample Matrix: Water

Lab ID#: 20210713831
Received: 07/13/21 at 12:00 PM
by System Account
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.700 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 07/15/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.870 | mg/L | 1 | | | Field Fluoride | JMH 07/14/21 |

Approved By: Steve Pistau

Approved On: 7/15/2021 4:47:09 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Scott Peterson Motors
Sampled: 07/08/21 at 08:40 AM
by Russel Abernathy

Purpose: Routine
EPA Number: 0321

Sample Matrix: Water Sturgis

Lab ID#: 20210708832
Received: 07/08/21 at 12:05 PM
by Eric Fuehrer

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.715 | mg/L | 1 | 0.008 | 0.050 | SM 4500 F-C | TMN 07/13/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.750 | mg/L | 1 | | | Field Fluoride | JMH 07/09/21 |

Approved By: Steve Distau

Approved On: 7/13/2021 10:03:09 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Ford Regulator (2418 Junction)
Sampled: 06/14/21 at 07:04 AM
by Brant
Purpose: Routine
EPA Number: 0321

Sturgis

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Matrix: Water
Lab ID#: 20210614808
Received: 06/14/21 at 08:55 AM
by Eric Fuehrer
Account: 8392

Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.519 | mg/L | 1 | 0.008 | 0.015 | SM 4500 F-C | TMN 06/15/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.740 | mg/L | 1 | | | Field Fluoride | SYS 06/14/21 |

Approved By: Steve Pistau

Approved On: 6/15/2021 1:35:32 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)
Sampled: 06/09/21 at 06:45 AM
by Russ Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20210609864
Received: 06/09/21 at 08:45 AM
by Jennifer Hill
Account: 8392

Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.518 | mg/L | 1 | 0.008 | 0.015 | SM 4500 F-C | TMN 06/15/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.690 | mg/L | 1 | | | Field Fluoride | JMH 06/10/21 |

Approved By: Steve Distau

Approved On: 6/15/2021 10:21:55 AM



31 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Sturgis Parks Dept. Shop
(1920 Ballpark A)
Sampled: 05/12/21 at 06:40 AM
by R. Abernathy
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20210512836
Received: 05/12/21 at 10:12 AM
by Jennifer Hill
Account: 8392

Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.540 | mg/L | 1 | 0.008 | 0.015 | SM 4500 F-C | TMN 05/13/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.700 | mg/L | 1 | | | Field Fluoride | JMH 05/13/21 |

Approved By: Steve Ristan

Approved On: 5/13/2021 2:30:49 PM



31 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: Butte Ridge Building E
(1900 Ellen St.)
Sampled: 05/06/21 at 07:28 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321
Sturgis
Sample Matrix: Water
Lab ID#: 20210506816
Received: 05/06/21 at 09:00 AM
by Avery Samuel
Account: 8392
Sturgis Water Company

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.559 | mg/L | 1 | 0.008 | 0.015 | SM 4500 F-C | TMN 05/11/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.920 | mg/L | 1 | | | Field Fluoride | JMH 05/07/21 |

Approved By: Steve Distau

Approved On: 5/11/2021 2:33:23 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: City Waterman
Sampled: 04/21/21 at 07:20 AM
by R. Abernathy
Purpose: Routine
EPA Number: 0321
Sturgis

Sample Matrix: Water

Lab ID#: 20210421810
Received: 04/21/21 at 10:30 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.621 | mg/L | 1 | 0.008 | 0.015 | SM 4500 F-C | TMN 04/23/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.980 | mg/L | 1 | | | Field Fluoride | SYS 04/22/21 |

Approved By: Steve Distau

Approved On: 4/26/2021 9:59:26 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Community Center (1401
Lazelle)
Sampled: 04/21/21 at 07:10 AM
by R. Abernathy
Purpose: Routine
EPA
Number: 0321

Sturgis

Sample
Matrix: Water

Lab ID#: 20210421811
Received: 04/21/21 at 10:30 AM
by Jennifer Hill
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.605 | mg/L | 1 | 0.008 | 0.015 | SM 4500 F-C | TMN 04/23/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.860 | mg/L | 1 | | | Field Fluoride | SYS 04/22/21 |

Approved By: Steve Distau

Approved On: 4/26/2021 9:59:26 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Pete Lien & Sons (2025 Sherman)
Sampled: 03/16/21 at 11:35 AM
by R. Abernathy
Purpose: Routine
EPA Number: 0321
Sample Matrix: Water
Lab ID#: 20210316867
Received: 03/16/21 at 12:35 PM
by Jennifer Hill
Account: 8392
Sturgis
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.585 | mg/L | 1 | 0.008 | 0.015 | SM 4500 F-C | TMN 03/17/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.900 | mg/L | 1 | | | Field Fluoride | SYS 03/17/21 |

Approved By: Steve Distau

Approved On: 3/17/2021 1:23:25 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Community Center (1401
Lazelle)

Sampled: 03/10/21 at 07:50 AM
by Russ Abernathy

Purpose: Routine

EPA
Number: 0321

Sturgis

Sample
Matrix: Water

Lab ID#: 20210310810

Received: 03/10/21 at 09:11 AM
by Avery Samuel

Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.615 | mg/L | 1 | 0.008 | 0.015 | SM 4500 F-C | TMN 03/11/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.760 | mg/L | 1 | | | Field Fluoride | JMH 03/10/21 |

Approved By: Steve Distau

Approved On: 3/12/2021 8:07:58 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Parks Dept. Shop
(1920 Ballpark A)
Sampled: 02/10/21 at 07:10 AM
by W. Hix
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20210210809
Received: 02/10/21 at 09:59 AM
by Jennifer Hill
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.585 | mg/L | 1 | 0.010 | 0.015 | SM 4500 F-C | SAA 02/18/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.850 | mg/L | 1 | | | Field Fluoride | SYS 02/11/21 |

Approved By: Steve Pistau

Approved On: 2/18/2021 12:45:15 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)
Sampled: 02/03/21 at 08:29 AM by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water
Lab ID#: 20210203817
Received: 02/03/21 at 10:00 AM by Jennifer Hill
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.515 | mg/L | 1 | 0.010 | 0.015 | SM 4500 F-C | AAS 02/04/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.860 | mg/L | 1 | | | Field Fluoride | JMH 02/04/21 |

Approved By: Steve Pistau

Approved On: 2/4/2021 11:51:19 AM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Rasmussen Mech. Services (3590 Mayor Ave)
Sampled: 01/25/21 at 09:33 AM by Wyatt
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20210125821
Received: 01/25/21 at 02:00 PM by System Account
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.534 | mg/L | 1 | 0.010 | 0.015 | SM 4500 F-C | SAA 01/28/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.920 | mg/L | 1 | | | Field Fluoride | SYS 01/26/21 |

Approved By: Steve Distau

Approved On: 1/28/2021 3:44:39 PM



381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Butte Ridge Building E
(1900 Ellen St.)
Sampled: 01/12/21 at 06:49 AM
by Brant Ager
Purpose: Routine
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20210112822
Received: 01/12/21 at 09:30 AM
by Sarah Ahlers
Account: 8392

Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

| Parameter | Result | Units | DF | MDL | PQL | Method | Analyst/Date |
|----------------------|--------|-------|----|-------|-------|----------------|--------------|
| Non-Metallics | | | | | | | |
| Fluoride | 0.537 | mg/L | 1 | 0.010 | 0.015 | SM 4500 F-C | SAA 01/13/21 |
| Field Test | | | | | | | |
| Field Fluoride | 0.910 | mg/L | 1 | | | Field Fluoride | JMH 01/13/21 |

Approved By: Steve Distau

Approved On: 1/14/2021 2:01:51 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 - www.thechemistrylab.com

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

Sample Site: WELL #7
Purpose: GWR Triggered
EPA Number: 0321
Sampled: 12/09/21 at 07:20 AM Sturgis
by T. Youngberg
Sample Matrix: Water
Lab ID#: 20211209808
Received: 12/09/21 at 09:48 AM
by Jennifer Hill
Account: 8392 - Sturgis Water
Company

| Parameter | Result | Units | DF | Method | Analyst/Date |
|-----------------|--------|-------|----|-----------------|--------------|
| Bacteria | | | | | |
| E. coli | Absent | | 1 | SM 9223 B (P/A) | JMH 12/09/21 |
| Total Coliform | Absent | | 1 | SM 9223 B (P/A) | JMH 12/09/21 |

Report Approved By: Steve Distau

Report Approved On: 12/10/2021 1:18:44 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Repeat
Received: 12/09/21 at 09:48 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|----------------------------|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 000 | 201 Old Stone | | 12/09/2021 09:02 AM | Absent | Absent | 0.46 mg/L | | JMH 12/09/2021 | 20211209805 |
| 0321 | 000 | 180 Old Stone | | 12/09/2021 08:07 AM | Absent | Absent | 0.66 mg/L | | JMH 12/09/2021 | 20211209806 |
| 0321 | 018 | Little Promises University | | 12/09/2021 07:56 AM | Absent | Absent | 0.89 mg/L | | JMH 12/09/2021 | 20211209807 |

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 12/10/2021 1:18:44 PM

DATE PRINTED: 12/10/2021 01:24 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 12/07/21 at 12:00 PM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 013 | Sturgis Water Shop (2901 Vanocker Canyon Rd) | | 12/07/2021 06:45 AM | Absent | Absent | 1.02 mg/L | | JMH 12/07/2021 | 20211207823 |
| 0321 | 015 | Sturgis Parks Dept. Shop (1920 Ballpark A) | | 12/07/2021 07:35 AM | Absent | Absent | 0.92 mg/L | | JMH 12/07/2021 | 20211207824 |
| 0321 | 017 | Northern Hills Vet Clinic | | 12/07/2021 08:15 AM | Absent | Absent | 0.95 mg/L | | JMH 12/07/2021 | 20211207825 |
| 0321 | 018 | Little Promises University | | 12/07/2021 08:30 AM | Present | Absent | 0.92 mg/L | | JMH 12/07/2021 | 20211207826 |

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 12/8/2021 3:25:56 PM

DATE PRINTED: 12/08/2021 03:36 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 12/02/21 at 10:15 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|---|--------------|---------------------|--------------------------------------|-------------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 004 | Rasmussen Mech. Services (3590 Mayor Ave) | | 12/02/2021 07:02 AM | Absent | Absent | 0.85 mg/L | | JMH 12/02/2021 | 20211202844 |
| 0321 | 007 | Community Center (1401 Lazelle) | | 12/02/2021 07:26 AM | Absent | Absent | 0.79 mg/L | | JMH 12/02/2021 | 20211202845 |
| 0321 | 009 | Loftus Dental Office (866 Lazelle) | | 12/02/2021 08:10 AM | Absent | Absent | 1.01 mg/L | | JMH 12/02/2021 | 20211202846 |
| 0321 | 020 | Liberty Chevrolet | | 12/02/2021 07:48 AM | Absent | Absent | 0.97 mg/L | | JMH 12/02/2021 | 20211202847 |

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 12/3/2021 3:07:13 PM

DATE PRINTED: 12/03/2021 03:17 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

91 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 11/15/21 at 10:23 AM
by Eric Fuehrer

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 000 | City Waterman | | 11/15/2021 09:15 AM | Absent | Absent | 1.14 mg/L | | JMH 11/15/2021 | 20211115817 |
| 0321 | 008 | Sturgis City Hall (1040 Harley-Davidson Way) | | 11/15/2021 08:15 AM | Absent | Absent | 0.89 mg/L | | JMH 11/15/2021 | 20211115818 |
| 0321 | 016 | Scott Peterson Motors | | 11/15/2021 07:30 AM | Absent | Absent | 0.59 mg/L | | JMH 11/15/2021 | 20211115819 |
| 0321 | 018 | Little Promises University | | 11/15/2021 08:30 AM | Absent | Absent | 1.04 mg/L | | JMH 11/15/2021 | 20211115820 |

REPORT APPROVED BY:

Steve Diston

REPORT APPROVED DATE: 11/16/2021 2:54:38 PM

DATE PRINTED: 11/16/2021 03:01 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

31 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 11/08/21 at 11:50 AM
by Bobbie Laurenz

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 006 | Butte Ridge Building E (1900 Ellen St.) | | 11/08/2021 08:30 AM | Absent | Absent | 0.86 mg/L | | SAA 11/08/2021 | 20211108831 |
| 0321 | 013 | Sturgis Water Shop (2901 Vanocker Canyon Rd) | | 11/08/2021 07:10 AM | Absent | Absent | 1.14 mg/L | | SAA 11/08/2021 | 20211108832 |
| 0321 | 014 | Ford Regulator (2418 Junction) | | 11/08/2021 06:50 AM | Absent | Absent | 1.14 mg/L | | SAA 11/08/2021 | 20211108833 |
| 0321 | 015 | Sturgis Parks Dept. Shop (1920 Ballpark A) | | 11/08/2021 07:40 AM | Absent | Absent | 1.11 mg/L | | SAA 11/08/2021 | 20211108834 |

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 11/10/2021 11:35:11 AM

DATE PRINTED: 11/10/2021 11:47 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

81 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 10/21/21 at 09:40 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 005 | Pete Lien & Sons (2025 Sherman) | | 10/21/2021 06:45 AM | Absent | Absent | 0.73 mg/L | | JMH 10/21/2021 | 20211021810 |
| 0321 | 010 | Schneider/Beckwith Dental (1245 Sherman) | | 10/21/2021 08:03 AM | Absent | Absent | 0.81 mg/L | | JMH 10/21/2021 | 20211021811 |
| 0321 | 011 | Sturgis Physical Therapy (1530 Junction) | | 10/21/2021 07:45 AM | Absent | Absent | 0.91 mg/L | | JMH 10/21/2021 | 20211021812 |
| 0321 | 019 | Heritage Acres Building | | 10/21/2021 07:02 AM | Absent | Absent | 1 mg/L | | JMH 10/21/2021 | 20211021813 |

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

10/22/2021 2:36:07 PM

DATE PRINTED:

10/22/2021 02:49 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 10/12/21 at 11:07 AM
by Eric Fuehrer

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 007 | Community Center (1401 Lazelle) | | 10/12/2021 08:05 AM | Absent | Absent | 1.24 mg/L | | JMH 10/12/2021 | 20211012826 |
| 0321 | 008 | Sturgis City Hall (1040 Harley-Davidson Way) | | 10/12/2021 09:05 AM | Absent | Absent | 0.64 mg/L | | JMH 10/12/2021 | 20211012827 |
| 0321 | 015 | Sturgis Parks Dept. Shop (1920 Ballpark A) | | 10/12/2021 07:45 AM | Absent | Absent | 0.99 mg/L | | JMH 10/12/2021 | 20211012828 |
| 0321 | 020 | Liberty Chevrolet | | 10/12/2021 08:45 AM | Absent | Absent | 1.21 mg/L | | JMH 10/12/2021 | 20211012829 |

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

10/13/2021 4:26:39 PM

DATE PRINTED:

10/13/2021 04:49 PM



MIDCONTINENT

TESTING LABORATORIES, INC

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 09/20/21 at 11:30 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 004 | Rasmussen Mech. Services (3590 Mayor Ave) | | 09/20/2021 08:00 AM | Absent | Absent | 0.89 mg/L | | JMH 09/20/2021 | 20210920840 |
| 0321 | 006 | Butte Ridge Building E (1900 Ellen St.) | | 09/20/2021 09:10 AM | Absent | Absent | 0.53 mg/L | | JMH 09/20/2021 | 20210920841 |
| 0321 | 013 | Sturgis Water Shop (2901 Vanocker Canyon Rd) | | 09/20/2021 07:45 AM | Absent | Absent | 0.58 mg/L | | JMH 09/20/2021 | 20210920842 |
| 0321 | 018 | Little Promises University | | 09/20/2021 08:30 AM | Absent | Absent | 0.49 mg/L | | JMH 09/20/2021 | 20210920843 |

REPORT APPROVED BY:

Steve Pistau

REPORT APPROVED DATE:

9/22/2021 8:38:39 AM

DATE PRINTED:

09/22/2021 08:41 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

81 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 09/14/21 at 09:30 AM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 008 | Sturgis City Hall (1040 Harley-Davidson Way) | | 09/14/2021 07:30 AM | Absent | Absent | 0.94 mg/L | | SAA 09/14/2021 | 20210914817 |
| 0321 | 014 | Ford Regulator (2418 Junction) | | 09/14/2021 07:18 AM | Absent | Absent | 0.58 mg/L | | SAA 09/14/2021 | 20210914818 |
| 0321 | 015 | Sturgis Parks Dept. Shop (1920 Ballpark A) | | 09/14/2021 08:14 AM | Absent | Absent | 1.06 mg/L | | SAA 09/14/2021 | 20210914819 |
| 0321 | 016 | Scott Peterson Motors | | 09/14/2021 08:35 AM | Absent | Absent | 0.56 mg/L | | SAA 09/14/2021 | 20210914820 |

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

9/16/2021 9:31:38 AM

DATE PRINTED:

09/16/2021 09:58 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

91 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 08/18/21 at 09:35 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 001 | G&G Enterprises (2251 Park Ave) | | 08/18/2021 06:49 AM | Absent | Absent | 0.77 mg/L | | JMH 08/18/2021 | 20210818805 |
| 0321 | 004 | Rasmussen Mech. Services (3590 Mayor Ave) | | 08/18/2021 07:08 AM | Absent | Absent | 0.84 mg/L | | JMH 08/18/2021 | 20210818806 |
| 0321 | 005 | Pete Lien & Sons (2025 Sherman) | | 08/18/2021 06:36 AM | Absent | Absent | 0.78 mg/L | | JMH 08/18/2021 | 20210818807 |
| 0321 | 013 | Sturgis Water Shop (2901 Vanocker Canyon Rd) | | 08/18/2021 07:38 AM | Absent | Absent | 0.61 mg/L | | JMH 08/18/2021 | 20210818808 |

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE: 8/19/2021 1:45:49 PM

DATE PRINTED: 08/19/2021 01:55 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 08/05/21 at 11:23 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 006 | Butte Ridge Building E (1900 Ellen St.) | | 08/05/2021 09:50 AM | Absent | Absent | 0.53 mg/L | | JMH 08/05/2021 | 20210805831 |
| 0321 | 007 | Community Center (1401 Lazelle) | | 08/05/2021 08:35 AM | Absent | Absent | 0.54 mg/L | | JMH 08/05/2021 | 20210805832 |
| 0321 | 011 | Sturgis Physical Therapy (1530 Junction) | | 08/05/2021 09:20 AM | Absent | Absent | 0.67 mg/L | | JMH 08/05/2021 | 20210805833 |
| 0321 | 019 | Heritage Acres Building | | 08/05/2021 08:10 AM | Absent | Absent | 0.97 mg/L | | JMH 08/05/2021 | 20210805834 |

REPORT APPROVED BY:

Jennifer Hill

REPORT APPROVED DATE:

8/9/2021 9:37:16 AM

DATE PRINTED:

08/09/2021 09:41 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

3381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 07/13/21 at 12:00 PM
by System Account
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 009 | Loftus Dental Office (866 Lazelle) | | 07/13/2021 09:53 AM | Absent | Absent | 1.16 mg/L | | JMH 07/13/2021 | 20210713827 |
| 0321 | 010 | Schneider/Beckwith Dental (1245 Sherman) | | 07/13/2021 09:35 AM | Absent | Absent | 1.05 mg/L | | JMH 07/13/2021 | 20210713828 |
| 0321 | 000 | 17 | | 07/13/2021 08:49 AM | Absent | Absent | 0.95 mg/L | | JMH 07/13/2021 | 20210713829 |
| 0321 | 000 | 19 | | 07/13/2021 09:08 AM | Absent | Absent | 1.24 mg/L | | JMH 07/13/2021 | 20210713830 |

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 7/14/2021 3:00:13 PM

DATE PRINTED: 07/14/2021 03:14 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 07/08/21 at 12:05 PM
by Eric Fuehrer

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 012 | Sturgis Regional Health (2100 Davenport) | | 07/08/2021 10:40 AM | Absent | Absent | 1.19 mg/L | | JMH 07/08/2021 | 20210708835 |
| 0321 | 016 | Scott Peterson Motors | | 07/08/2021 08:40 AM | Absent | Absent | 0.51 mg/L | | JMH 07/08/2021 | 20210708836 |
| 0321 | 018 | Little Promises University | | 07/08/2021 08:55 AM | Absent | Absent | 0.64 mg/L | | JMH 07/08/2021 | 20210708837 |
| 0321 | 020 | Liberty Chevrolet | | 07/08/2021 09:55 AM | Absent | Absent | 1.21 mg/L | | JMH 07/08/2021 | 20210708838 |

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

7/9/2021 3:41:36 PM

DATE PRINTED:

07/09/2021 03:53 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

31 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 06/14/21 at 08:55 AM
by Eric Fuehrer

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 007 | Community Center (1401 Lazelle) | | 06/14/2021 06:37 AM | Absent | Absent | 0.47 mg/L | | JMH 06/14/2021 | 20210614804 |
| 0321 | 008 | Sturgis City Hall (1040 Harley-Davidson Way) | | 06/14/2021 07:24 AM | Absent | Absent | 0.3 mg/L | | JMH 06/14/2021 | 20210614805 |
| 0321 | 014 | Ford Regulator (2418 Junction) | | 06/14/2021 07:00 AM | Absent | Absent | 0.73 mg/L | | JMH 06/14/2021 | 20210614806 |

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

6/15/2021 1:35:32 PM

DATE PRINTED:

06/15/2021 01:47 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

31 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine
Received: 06/09/21 at 08:45 AM
by Jennifer Hill
Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 005 | Pete Lien & Sons (2025 Sherman) | | 06/09/2021 07:50 AM | Absent | Absent | 0.5 mg/L | | JMH 06/09/2021 | 20210609810 |
| 0321 | 006 | Butte Ridge Building E (1900 Ellen St.) | | 06/09/2021 07:35 AM | Absent | Absent | 0.85 mg/L | | JMH 06/09/2021 | 20210609811 |
| 0321 | 013 | Sturgis Water Shop (2901 Vanocker Canyon Rd) | | 06/09/2021 06:45 AM | Absent | Absent | 0.75 mg/L | | JMH 06/09/2021 | 20210609812 |
| 0321 | 015 | Sturgis Parks Dept. Shop (1920 Ballpark A) | | 06/09/2021 07:15 AM | Absent | Absent | 1.09 mg/L | | JMH 06/09/2021 | 20210609813 |

REPORT APPROVED BY: Steve Pistau

REPORT APPROVED DATE: 6/10/2021 2:30:17 PM

DATE PRINTED: 06/10/2021 02:35 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 05/12/21 at 10:12 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 000 | City Waterman | | 05/12/2021 07:00 AM | Absent | Absent | 1.19 mg/L | | JMH 05/12/2021 | 20210512808 |
| 0321 | 007 | Community Center (1401 Lazelle) | | 05/12/2021 07:15 AM | Absent | Absent | 1.07 mg/L | | JMH 05/12/2021 | 20210512809 |
| 0321 | 014 | Ford Regulator (2418 Junction) | | 05/12/2021 07:35 AM | Absent | Absent | 0.92 mg/L | | JMH 05/12/2021 | 20210512810 |
| 0321 | 015 | Sturgis Parks Dept. Shop (1920 Ballpark A) | | 05/12/2021 06:40 AM | Absent | Absent | 0.76 mg/L | | JMH 05/12/2021 | 20210512811 |

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 5/13/2021 2:30:49 PM

DATE PRINTED: 05/13/2021 02:41 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

91 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 05/06/21 at 09:00 AM
by Avery Samuel

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 006 | Butte Ridge Building E (1900 Ellen St.) | | 05/06/2021 07:30 AM | Absent | Absent | 1.06 mg/L | | JMH 05/06/2021 | 20210506808 |
| 0321 | 008 | Sturgis City Hall (1040 Harley-Davidson Way) | | 05/06/2021 07:49 AM | Absent | Absent | 1 mg/L | | JMH 05/06/2021 | 20210506809 |
| 0321 | 013 | Sturgis Water Shop (2901 Vanocker Canyon Rd) | | 05/06/2021 08:10 AM | Absent | Absent | 1.26 mg/L | | JMH 05/06/2021 | 20210506810 |

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

5/7/2021 1:16:44 PM

DATE PRINTED:

05/07/2021 01:35 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

81 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 04/21/21 at 10:30 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 000 | City Waterman | | 04/21/2021 07:20 AM | Absent | Absent | 1.26 mg/L | | JMH 04/21/2021 | 20210421807 |
| 0321 | 007 | Community Center (1401 Lazelle) | | 04/21/2021 07:10 AM | Absent | Absent | 1.19 mg/L | | JMH 04/21/2021 | 20210421808 |
| 0321 | 015 | Sturgis Parks Dept. Shop (1920 Ballpark A) | | 04/21/2021 07:00 AM | Absent | Absent | 0.8 mg/L | | JMH 04/21/2021 | 20210421809 |

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 4/22/2021 3:18:40 PM

DATE PRINTED: 04/22/2021 03:23 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 04/14/21 at 09:10 AM
by Avery Samuel

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 001 | G&G Enterprises (2251 Park Ave) | | 04/14/2021 07:00 AM | Absent | Absent | 1.17 mg/L | | JMH 04/14/2021 | 20210414807 |
| 0321 | 008 | Sturgis City Hall (1040 Harley-Davidson Way) | | 04/14/2021 07:15 AM | Absent | Absent | 0.79 mg/L | | JMH 04/14/2021 | 20210414808 |
| 0321 | 009 | Loftus Dental Office (866 Lazelle) | | 04/14/2021 07:48 AM | Absent | Absent | 0.43 mg/L | | JMH 04/14/2021 | 20210414809 |
| 0321 | 014 | Ford Regulator (2418 Junction) | | 04/14/2021 07:31 AM | Absent | Absent | 0.37 mg/L | | JMH 04/14/2021 | 20210414810 |

REPORT APPROVED BY:

Jennifer Hill

REPORT APPROVED DATE:

4/15/2021 4:13:39 PM

DATE PRINTED:

04/15/2021 04:15 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

3381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 03/16/21 at 12:35 PM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|---|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 002 | National Guard (701 14th St.) | | 03/16/2021 11:15 AM | Absent | Absent | 1.13 mg/L | | JMH 03/16/2021 | 20210316811 |
| 0321 | 004 | Rasmussen Mech. Services (3590 Mayor Ave) | | 03/16/2021 10:55 AM | Absent | Absent | 0.92 mg/L | | JMH 03/16/2021 | 20210316812 |
| 0321 | 005 | Pete Lien & Sons (2025 Sherman) | | 03/16/2021 11:35 AM | Absent | Absent | 1.06 mg/L | | JMH 03/16/2021 | 20210316813 |

REPORT APPROVED BY: Steve Pistau

REPORT APPROVED DATE: 3/17/2021 1:23:25 PM

DATE PRINTED: 03/17/2021 01:40 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 03/10/21 at 09:11 AM
by Avery Samuel

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 007 | Community Center (1401 Lazelle) | | 03/10/2021 07:50 AM | Absent | Absent | 1.26 mg/L | | JMH 03/10/2021 | 20210310802 |
| 0321 | 008 | Sturgis City Hall (1040 Harley-Davidson Way) | | 03/10/2021 07:30 AM | Absent | Absent | 1.57 mg/L | | JMH 03/10/2021 | 20210310803 |
| 0321 | 013 | Sturgis Water Shop (2901 Vanocker Canyon Rd) | | 03/10/2021 06:50 AM | Absent | Absent | 1.3 mg/L | | JMH 03/10/2021 | 20210310804 |
| 0321 | 015 | Sturgis Parks Dept. Shop (1920 Ballpark A) | | 03/10/2021 07:15 AM | Absent | Absent | 1.09 mg/L | | JMH 03/10/2021 | 20210310805 |

REPORT APPROVED BY:

Steve Pistau

REPORT APPROVED DATE:

3/12/2021 8:07:58 AM

DATE PRINTED:

03/12/2021 08:33 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 02/10/21 at 09:59 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 006 | Butte Ridge Building E (1900 Ellen St.) | | 02/10/2021 07:34 AM | Absent | Absent | 0.89 mg/L | | JMH 02/10/2021 | 20210210806 |
| 0321 | 007 | Community Center (1401 Lazelle) | | 02/10/2021 07:58 AM | Absent | Absent | 1.02 mg/L | | JMH 02/10/2021 | 20210210807 |
| 0321 | 015 | Sturgis Parks Dept. Shop (1920 Ballpark A) | | 02/10/2021 07:15 AM | Absent | Absent | 0.79 mg/L | | JMH 02/10/2021 | 20210210808 |

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 2/11/2021 12:40:27 PM

DATE PRINTED: 02/11/2021 12:52 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

281 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 02/03/21 at 10:00 AM
by Jennifer Hill

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 001 | G&G Enterprises (2251 Park Ave) | | 02/03/2021 07:50 AM | Absent | Absent | 0.95 mg/L | | JMH 02/03/2021 | 20210203809 |
| 0321 | 003 | Speedy Lube (2205 Park Ave) | | 02/03/2021 08:04 AM | Absent | Absent | 0.96 mg/L | | JMH 02/03/2021 | 20210203810 |
| 0321 | 005 | Pete Lien & Sons (2025 Sherman) | | 02/03/2021 07:32 AM | Absent | Absent | 1.02 mg/L | | JMH 02/03/2021 | 20210203811 |
| 0321 | 013 | Sturgis Water Shop (2901 Vanocker Canyon Rd) | | 02/03/2021 08:27 AM | Absent | Absent | 0.62 mg/L | | JMH 02/03/2021 | 20210203812 |

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

2/4/2021 11:20:29 AM

DATE PRINTED:

02/04/2021 11:25 AM



MIDCONTINENT
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 01/25/21 at 02:45 PM
by System Account

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 004 | Rasmussen Mech. Services (3590 Mayor Ave) | | 01/25/2021 10:00 AM | Absent | Absent | 0.69 mg/L | | SCR 01/25/2021 | 20210125828 |
| 0321 | 013 | Sturgis Water Shop (2901 Vanocker Canyon Rd) | | 01/25/2021 10:30 AM | Absent | Absent | 0.55 mg/L | | SCR 01/25/2021 | 20210125829 |
| 0321 | 015 | Sturgis Parks Dept. Shop (1920 Ballpark A) | | 01/25/2021 10:52 AM | Absent | Absent | 0.51 mg/L | | SCR 01/25/2021 | 20210125830 |

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 1/26/2021 12:41:17 PM

DATE PRINTED: 01/26/2021 12:55 PM



MIDCONTINENT
TESTING LABORATORIES, INC.

281 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 01/12/21 at 09:30 AM
by Sarah Ahlers

Account: 8392
Sturgis Water Company

RICK BUSH
STURGIS WATER COMPANY
1040 HARLEY-DAVIDSON WAY
STURGIS, SD 57785

MUNICIPAL DRINKING WATER REPORT

| EPA # | SITE # | SAMPLE SITE | SAMPLE POINT | SAMPLE DATE & TIME | TOTAL COLIFORM SM 9223 B (P/A) | E. COLI SM 9223 B (P/A) | FIELD TESTS | | ANALYST | LAB NUMBER |
|-------|--------|--|--------------|---------------------|--------------------------------|-------------------------|-------------|----|----------------|-------------|
| | | | | | | | RESIDUAL CL | PH | | |
| 0321 | 006 | Butte Ridge Building E (1900 Ellen St.) | | 01/12/2021 06:45 AM | Absent | Absent | 0.67 mg/L | | SAA 01/12/2021 | 20210112810 |
| 0321 | 007 | Community Center (1401 Lazelle) | | 01/12/2021 07:05 AM | Absent | Absent | 1.08 mg/L | | SAA 01/12/2021 | 20210112811 |
| 0321 | 008 | Sturgis City Hall (1040 Harley-Davidson Way) | | 01/12/2021 08:05 AM | Absent | Absent | 0.71 mg/L | | SAA 01/12/2021 | 20210112812 |
| 0321 | 014 | Ford Regulator (2418 Junction) | | 01/12/2021 07:32 AM | Absent | Absent | 0.48 mg/L | | SAA 01/12/2021 | 20210112813 |

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 1/13/2021 1:39:48 PM

DATE PRINTED: 01/13/2021 01:52 PM