



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: WELL #7  
Sampled: 11/01/22 at 08:50 AM  
by Russ Abernatny  
Purpose: Routine  
EPA Number: 0321  
Sturgis  
Sample Matrix: Water

Lab ID#: 20221101902  
Received: 11/01/22 at 09:45 AM  
by Greg McDougall  
Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Nitrogen, Nitrate (NO3)	0.437	mg/L	1	0.008	0.050	SM 4500-NO3 F	BLL 11/02/22

Approved By: Steve Disten

Approved On: 11/3/2022 3:07:34 PM



2281 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: BHSS  
Sampled: 09/12/22 at 09:20 AM  
Purpose: Routine  
EPA Number: 0321

Sturgis  
Sample Matrix: Water

Lab ID#: 20220912905  
Received: 09/12/22 at 09:55 AM  
by Dean Aurand  
Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b><u>Volatile</u></b>							
Bromodichloromethane	< 0.500	µg/L	1	0.010	0.500	EPA 524.2	RAM 09/16/22
Bromoform	< 0.500	µg/L	1	0.013	0.500	EPA 524.2	RAM 09/16/22
Chlorodibromomethane	< 0.500	µg/L	1	0.009	0.500	EPA 524.2	RAM 09/16/22
Chloroform	< 0.500	µg/L	1	0.009	0.500	EPA 524.2	RAM 09/16/22
<b><u>Calculated Totals</u></b>							
Total Haloacetic Acids	< 15.0	µg/L	1	0.566	15.0	EPA 552.2	SAC 10/02/22
Total Trihalomethanes	< 2.00	µg/L	1	0.043	2.00	EPA 524.2	RAM 09/22/22
<b><u>Semi-Volatile</u></b>							
Dibromoacetic acid	< 2.50	µg/L	1	0.244	2.50	EPA 552.2	SAC 10/02/22
Dichloroacetic acid	< 2.50	µg/L	1	0.302	2.50	EPA 552.2	SAC 10/02/22
Monobromoacetic acid	< 2.50	µg/L	1	0.138	2.50	EPA 552.2	SAC 10/02/22
Monochloroacetic acid	< 5.00	µg/L	1	0.259	5.00	EPA 552.2	SAC 10/02/22
Trichloroacetic acid	< 2.50	µg/L	1	0.394	2.50	EPA 552.2	SAC 10/02/22

Approved By: Steve Distau

Approved On: 10/31/2022 8:35:06 AM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

2304 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Received: 11/03/22 at 02:30 PM  
by System Account  
Account: 9947  
Wilson Contracting, LLC

DOUG WILSON  
WILSON CONTRACTING, LLC  
21652 PIEDMONT MEADOWS  
PIEDMONT, SD 57769

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	FH on Pine Glenn <sub>1</sub>	South End	11/03/22 01:50 PM	Absent	Absent		JMH 11/03/2022	20221103842

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 11/4/2022 2:08:13 PM

DATE PRINTED: 11/04/2022 02:15 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

23<sup>rd</sup> South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Received: 11/02/22 at 03:00 PM  
by System Account  
Account: 9947  
Wilson Contracting, LLC

DOUG WILSON  
WILSON CONTRACTING, LLC  
21652 PIEDMONT MEADOWS  
PIEDMONT, SD 57769

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	End of Pine Glenn St.1	S Hydrant	11/02/22 02:00 PM	Absent	Absent		SAA 11/02/2022	20221102828

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY:

Steve Ristan

REPORT APPROVED DATE:

11/4/2022 9:39:17 AM

DATE PRINTED:

11/04/2022 09:47 AM



DOUG WILSON  
WILSON CONTRACTING, LLC  
21652 PIEDMONT MEADOWS  
PIEDMONT, SD 57769

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	FH on Pine Glenn <sub>1</sub>		10/18/22 12:45 PM	Absent	Absent		JMH 10/18/2022	20221018873

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 10/19/2022 3:05:10 PM

DATE PRINTED: 10/19/2022 03:11 PM

Dolan Cr. Rd. N.  
to ~~D~~ Dolan Cr. Rd. S.  
on Pine Glenn  
  
Sample #2



DOUG WILSON  
WILSON CONTRACTING, LLC  
21652 PIEDMONT MEADOWS  
PIEDMONT, SD 57769

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	FH on Pine Glenn1		10/17/22 12:20 PM	Absent	Absent		JMH 10/17/2022	20221017849

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 10/19/2022 9:05:57 AM

DATE PRINTED: 10/19/2022 09:16 AM

*Dolan Cr. Rd N.  
to Dolan Cr. Rd. S  
on Pine Glenn  
Sample #1*



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Received: 07/19/22 at 12:22 PM  
by Eric Fuehrer  
Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Grab Sample <sub>1</sub>		07/19/22 09:22 AM	Absent	Absent		JMH 07/19/2022	20220719822

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 7/20/2022 2:31:37 PM

DATE PRINTED: 07/20/2022 02:37 PM

*Hidden Hills  
follow up sample*



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Received: 04/07/22 at 12:05 PM  
by Jennifer Hill  
Account: 9947  
Wilson Contracting, LLC

DOUG WILSON  
WILSON CONTRACTING, LLC  
21652 PIEDMONT MEADOWS  
PIEDMONT, SD 57769

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	FH @ end for Low Pressure <sub>1</sub>		04/07/22 10:25 AM	Absent	Absent		JMH 04/07/2022	20220407821

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 4/8/2022 2:17:36 PM

DATE PRINTED: 04/08/2022 02:21 PM





**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Received: 04/07/22 at 12:05 PM  
by Jennifer Hill  
Account: 9947  
Wilson Contracting, LLC

DOUG WILSON  
WILSON CONTRACTING, LLC  
21652 PIEDMONT MEADOWS  
PIEDMONT, SD 57769

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	FH @ N. end for High Pressure <sub>1</sub>		04/07/22 11:20 AM	Absent	Absent		JMH 04/07/2022	20220407822

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 4/8/2022 2:17:36 PM

DATE PRINTED: 04/08/2022 02:21 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

2001 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Received: 04/05/22 at 12:27 PM  
by Jennifer Hill  
Account: 9947  
Wilson Contracting, LLC

DOUG WILSON  
WILSON CONTRACTING, LLC  
21652 PIEDMONT MEADOWS  
PIEDMONT, SD 57769

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	FH @ N. end for High Pressure <sub>1</sub>		04/05/22 11:25 AM	Absent	Absent		JMH 04/05/2022	20220405846

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 4/6/2022 3:07:49 PM

DATE PRINTED: 04/06/2022 03:21 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

2024 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Received: 04/05/22 at 12:27 PM  
by Jennifer Hill  
Account: 9947  
Wilson Contracting, LLC

DOUG WILSON  
WILSON CONTRACTING, LLC  
21652 PIEDMONT MEADOWS  
PIEDMONT, SD 57769

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	FH @ end for Low Pressure <sub>1</sub>		04/05/22 11:50 AM	Absent	Absent		JMH 04/05/2022	20220405847

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 4/6/2022 3:07:49 PM

DATE PRINTED: 04/06/2022 03:21 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

2024 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Received: 03/31/22 at 01:50 PM  
by Jennifer Hill  
Account: 9844  
Severson Dirt Works, LLC.

SEVERSON DIRT WORKS, LLC.  
202 9TH ST.  
STURGIS, SD 57785

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Dolan Creek Senior Housing <sub>1</sub>	6" Fire line	03/31/22 11:00 AM	Absent	Absent		JMH 03/31/2022	20220331819
	Dolan Creek Senior Housing <sub>1</sub>	4" Service line	03/31/22 10:30 AM	Absent	Absent		JMH 03/31/2022	20220331820

**Key to Notes:**

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 4/1/2022 2:14:45 PM

DATE PRINTED: 04/01/2022 02:19 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Received: 03/28/22 at 12:40 PM  
by Eric Fuehrer  
Account: 9844  
Severson Dirt Works, LLC.

SEVERSON DIRT WORKS, LLC.  
202 9TH ST.  
STURGIS, SD 57785

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	Dolan Creek Senior Housing <sub>1</sub>	service line	03/28/22 11:30 AM	Absent	Absent		SAA 03/28/22	20220328806
	Dolan Creek Senior Housing <sub>1</sub>	fire line	03/28/22 11:30 AM	Absent	Absent		SAA 03/28/2022	20220328807

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/29/2022 3:19:35 PM

DATE PRINTED: 03/29/2022 03:25 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Received: 03/07/22 at 10:00 AM  
by Sarah Ahlers  
Account: 9947  
Wilson Contracting, LLC

DOUG WILSON  
WILSON CONTRACTING, LLC  
21652 PIEDMONT MEADOWS  
PIEDMONT, SD 57769

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	FH North of Jose <sub>1</sub>		03/07/22 08:00 AM	Absent	Absent		JMH 03/07/2022	20220307803

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

3/8/2022 2:09:21 PM

DATE PRINTED:

03/08/2022 02:27 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Received: 03/03/22 at 10:00 AM  
by Jennifer Hill  
Account: 9947  
Wilson Contracting, LLC

DOUG WILSON  
WILSON CONTRACTING, LLC  
21652 PIEDMONT MEADOWS  
PIEDMONT, SD 57769

**DRINKING WATER REPORT**

EPA #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	NITRATE	ANALYST	LAB NUMBER
	FH North of Josej		03/03/22 09:40 AM	Absent	Absent		JMH 03/03/2022	20220303810

Key to Notes:

- 1. Bacteriologically safe for drinking or washing uncooked foods at the time of sampling.

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/4/2022 3:00:24 PM

DATE PRINTED: 03/04/2022 03:13 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: G&G Enterprises (2251 Park Ave)  
Sampled: 12/12/22 at 07:00 AM  
by Jesse Banek  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20221212820  
Received: 12/12/22 at 10:00 AM  
by System Account  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.763	mg/L	1	0.003	0.010	SM 4500 F-C	TMN 12/14/22
<b>Field Test</b>							
Field Fluoride	0.920	mg/L	1			Field Fluoride	JMH 12/13/22

Approved By: Steve Distau

Approved On: 12/14/2022 1:01:38 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Site: Pete Lien & Sons (2025 Sherman)  
Sampled: 12/06/22 at 07:30 AM  
by Russ  
Purpose: Routine  
EPA Number: 0321  
Sample Matrix: Water  
Lab ID#: 20221206880  
Received: 12/06/22 at 10:45 AM  
by Eric Fuehrer  
Account: 8392

Sturgis

Sturgis Water Company

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	0.540	mg/L	SM 4500 F-C	JMH 12/08/22
<b>Field Test</b>				
Field Fluoride	0.680	mg/L	Field Fluoride	SYS 12/07/22

Approved By: Steve Ristau

Approved On: 12/9/2022 9:07:29 AM



South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Ford Regulator (2418 Junction)

Sampled: 11/08/22 at 07:00 AM  
by Jesse Banek

Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20221108875  
Received: 11/08/22 at 11:00 AM  
by System Account

Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	0.724	mg/L	SM 4500 F-C	TMN 11/10/22
<b>Field Test</b>				
Field Fluoride	0.840	mg/L	Field Fluoride	JMH 11/09/22

Approved By: Steve Distau

Approved On: 11/10/2022 12:40:24 PM



2201 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)  
Sampled: 11/01/22 at 06:30 AM  
by Russ Abernatny  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water  
Lab ID#: 20221101837  
Received: 11/01/22 at 09:00 AM  
by System Account  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.826	mg/L	1			SM 4500 F-C	TMN 11/03/22
<b>Field Test</b>							
Field Fluoride	1.00	mg/L	1			Field Fluoride	JMH 11/02/22

Approved By: Steve Disten

Approved On: 11/4/2022 8:23:53 AM



11 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Community Center (1401 Lazelle)  
Sampled: 10/12/22 at 07:58 AM  
by Russ  
Purpose: Routine  
EPA Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water

Lab ID#: 20221012868  
Received: 10/12/22 at 10:15 AM  
by Eric Fuehrer  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.810	mg/L	1			SM 4500 F-C	TMN 10/16/22
<b>Field Test</b>							
Field Fluoride	0.790	mg/L	1			Field Fluoride	JMH 10/13/22

Approved By: Steve Pistau

Approved On: 10/18/2022 2:10:06 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Butte Ridge Building E  
(1900 Ellen St.)  
Sampled: 10/03/22 at 07:00 AM  
by Brant  
Purpose: Routine  
EPA  
Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water

Lab ID#: 20221003835  
Received: 10/03/22 at 12:45 PM  
by System Account  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	Method	Analyst/Date
<u>Non-Metallics</u>				
Fluoride	1.03	mg/L	SM 4500 F-C	TMN 10/05/22

Approved By: Steve Pistau

Approved On: 10/6/2022 8:06:54 AM



2281 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Parks Dept. Shop  
(1920 Ballpark A)  
Sampled: 09/20/22 at 06:45 AM  
by Russ Abernatry  
Purpose: Routine  
EPA Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water  
Lab ID#: 20220920846  
Received: 09/20/22 at 10:25 AM  
by Mara Mechaley  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	0.731	mg/L	SM 4500 F-C	TMN 09/21/22
<b>Field Test</b>				
Field Fluoride	0.860	mg/L	Field Fluoride	JMH 09/21/22

Approved By: Steve Distau

Approved On: 9/22/2022 9:14:59 AM



181 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Ford Regulator (2418 Junction)  
Sampled: 09/12/22 at 06:45 AM by JB  
Purpose: Routine  
EPA Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water  
Lab ID#: 20220912836  
Received: 09/12/22 at 09:50 AM by System Account  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	Method	Analyst/Date
<u>Non-Metallics</u>				
Fluoride	0.898	mg/L	SM 4500 F-C TMN	09/13/22

Approved By: Steve Pistau

Approved On: 9/14/2022 10:14:27 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis City Hall (1040 Harley-Davidson Way)  
Sampled: 08/16/22 at 07:15 AM  
by Brant Ager  
Purpose: Routine  
EPA Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water

Lab ID#: 20220816869  
Received: 08/16/22 at 10:15 AM  
by Eric Fuehrer  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	1.20	mg/L	SM 4500 F-C	TMN 08/17/22
<b>Field Test</b>				
Field Fluoride	1.23	mg/L	Field Fluoride	JMH 08/17/22

Approved By: Steve Distau

Approved On: 8/17/2022 3:18:40 PM





11 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Community Center (1401  
Lazelle)  
Sampled: 08/01/22 at 07:45 AM  
by Russell  
Purpose: Routine  
EPA  
Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample  
Matrix: Water

Lab ID#: 20220801837  
Received: 08/01/22 at 11:38 AM  
by Eric Fuehrer  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	1.23	mg/L	SM 4500 F-C	TMN 08/02/22
<b>Field Test</b>				
Field Fluoride	1.22	mg/L	Field Fluoride	JMH 08/01/22

Approved By: Steve Pistau

Approved On: 8/3/2022 8:18:56 AM



31 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)  
Sampled: 07/12/22 at 09:40 AM  
by Brant Ager  
Purpose: Routine  
EPA Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water

Lab ID#: 20220712912  
Received: 07/12/22 at 11:00 AM  
by System Account  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	0.820	mg/L	SM 4500 F-C	TMN 07/14/22
<b>Field Test</b>				
Field Fluoride	0.760	mg/L	Field Fluoride	JMH 07/14/22

Approved By: Steve Ristau

Approved On: 7/19/2022 1:48:19 PM



11 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Pete Lien & Sons (2025 Sherman)  
Sampled: 07/06/22 at 07:05 AM  
by Russ Abernatny  
Purpose: Routine  
EPA Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water  
Lab ID#: 20220706884  
Received: 07/06/22 at 09:56 AM  
by Dean Aurand  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	1.09	mg/L	1	0.005	0.050	SM 4500 F-C	TMN 07/08/22
<b>Field Test</b>							
Field Fluoride	1.13	mg/L	1			Field Fluoride	JMH 07/07/22

Approved By: Steve Distau

Approved On: 7/11/2022 9:45:16 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Ford Regulator (2418 Junction)  
Sampled: 06/15/22 at 07:21 AM  
by Brant Ager  
Purpose: Routine  
EPA Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water  
Lab ID#: 20220615838  
Received: 06/15/22 at 09:47 AM  
by Eric Fuehrer  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.789	mg/L	1	0.005	0.050	SM 4500 F-C	TMN 06/20/22
<b>Field Test</b>							
Field Fluoride	1.12	mg/L	1			Field Fluoride	JMH 06/15/22

Approved By: Steve Pistau

Approved On: 6/21/2022 8:31:13 AM



11 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)  
Sampled: 06/06/22 at 07:00 AM  
by Russ Abernatny  
Purpose: Routine  
EPA Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water

Lab ID#: 20220606929  
Received: 06/06/22 at 09:00 AM  
by System Account  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.749	mg/L	1	0.005	0.050	SM 4500 F-C	TMN 06/08/22
<b>Field Test</b>							
Field Fluoride	0.830	mg/L	1			Field Fluoride	JMH 06/08/22

Approved By: Steve Pistau

Approved On: 6/8/2022 1:23:51 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Community Center (1401  
Lazelle)  
Sampled: 05/16/22 at 06:45 AM  
by Brant Ager  
Purpose: Routine  
EPA  
Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water  
  
Lab ID#: 20220516837  
Received: 05/16/22 at 10:44 AM  
by Jennifer Hill  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	1.20	mg/L	1	0.005	0.050	SM 4500 F-C	TMN 05/17/22
<b>Field Test</b>							
Field Fluoride	1.53	mg/L	1			Field Fluoride	JMH 05/16/22

Approved By: Steve Ristau

Approved On: 5/17/2022 3:45:52 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Butte Ridge Building E  
(1900 Ellen St.)  
Sampled: 05/09/22 at 11:15 AM  
by R. Abernathy  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20220509830  
Received: 05/09/22 at 01:00 PM  
by System Account  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	1.34	mg/L	1	0.005	0.050	SM 4500 F-C	TMN 05/12/22
<b>Field Test</b>							
Field Fluoride	1.30	mg/L	1			Field Fluoride	SYS 05/09/22

Approved By: Steve Pistau

Approved On: 5/12/2022 2:08:50 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)  
Sampled: 04/11/22 at 06:51 AM  
by Brant Ager  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20220411813  
Received: 04/11/22 at 10:00 AM  
by Jennifer Hill  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	1.31	mg/L	1	0.005	0.050	SM 4500 F-C	TMN 04/13/22
<b>Field Test</b>							
Field Fluoride	1.59	mg/L	1			Field Fluoride	SYS 04/12/22

Approved By: Steve Pistau

Approved On: 4/13/2022 3:17:30 PM





11 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: National Guard (701 14th St.)

Sampled: 04/07/22 at 07:30 AM  
by Russell Abernathy

Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20220407815  
Received: 04/07/22 at 10:30 AM  
by Jennifer Hill

Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	1.25	mg/L	1	0.005	0.050	SM 4500 F-C	TMN 04/08/22
<b>Field Test</b>							
Field Fluoride	1.33	mg/L	1			Field Fluoride	JMH 04/08/22

Approved By: Steve Pistau

Approved On: 4/11/2022 10:30:32 AM



11 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Site: Scott Peterson Motors  
Sampled: 03/15/22 at 07:46 AM  
by W. Hix  
Purpose: Routine  
EPA Number: 0321  
Sturgis  
Sample Matrix: Water  
Lab ID#: 20220315818  
Received: 03/15/22 at 11:15 AM  
by Eric Fuehrer  
Account: 8392  
Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.942	mg/L	1	0.005	0.050	SM 4500 F-C	TMN 03/17/22
<b>Field Test</b>							
Field Fluoride	1.06	mg/L	1			Field Fluoride	SYS 03/16/22

Approved By: Steve Pistau

Approved On: 3/17/2022 11:20:42 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Pete Lien & Sons (2025 Sherman)  
Sampled: 03/09/22 at 06:41 AM  
by Brant  
Purpose: Routine  
EPA Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water

Lab ID#: 20220309820  
Received: 03/09/22 at 09:45 AM  
by Jennifer Hill  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	1.17	mg/L	1	0.005	0.050	SM 4500 F-C	TMN 03/10/22
<b>Field Test</b>							
Field Fluoride	1.35	mg/L	1			Field Fluoride	SYS 03/10/22

Approved By: Steve Pistau

Approved On: 3/11/2022 11:31:51 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Site: Sturgis City Hall (1040 Harley-Davidson Way)  
Sampled: 02/17/22 at 07:30 AM by R. Abernathy  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20220217821  
Received: 02/17/22 at 12:25 PM by System Account  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	1.33	mg/L	1	0.008	0.050	SM 4500 F-C	TNA 02/18/22
<b>Field Test</b>							
Field Fluoride	1.51	mg/L	1			Field Fluoride	SYS 02/18/22

Approved By: Steve Distau

Approved On: 2/18/2022 3:27:05 PM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)  
Sampled: 02/07/22 at 07:30 AM  
by W. Hix  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20220207826  
Received: 02/07/22 at 11:45 AM  
by Steve Ristau  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.569	mg/L	1	0.008	0.050	SM 4500 F-C	TMN 02/12/22
<b>Field Test</b>							
Field Fluoride	0.760	mg/L	1			Field Fluoride	SYS 02/07/22

Approved By: Steve Ristau

Approved On: 2/14/2022 8:05:16 AM



1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Community Center (1401  
Lazelle)  
Sampled: 01/27/22 at 06:39 AM  
by BA  
Purpose: Routine  
EPA  
Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample  
Matrix: Water

Lab ID#: 20220127819  
Received: 01/27/22 at 09:48 AM  
by Jennifer Hill  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	1.40	mg/L	1	0.008	0.050	SM 4500 F-C	TMN 02/01/22
<b>Field Test</b>							
Field Fluoride	1.37	mg/L	1			Field Fluoride	SYS 01/28/22

Approved By: Steve Distau

Approved On: 2/1/2022 12:39:50 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: **Scott Peterson Motors**  
Sampled: 01/04/22 at 07:30 AM  
by Russ Abernatny  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20220104876  
Received: 01/04/22 at 12:00 PM  
by System Account

Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.702	mg/L	1	0.008	0.050	SM 4500 F-C	TMN 01/05/22
<b>Field Test</b>							
Field Fluoride	0.870	mg/L	1			Field Fluoride	JMH 01/05/22

Approved By: Steve Pistau

Approved On: 1/6/2022 1:30:30 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 12/12/22 at 10:00 AM  
by System Account

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (PIA)	E. COLI SM 9223 B (PIA)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		12/12/2022 07:00 AM	Absent	Absent	0.9 mg/L		JMH 12/12/2022	20221212815
0321	006	Butte Ridge Building E (1900 Ellen St.)		12/12/2022 06:40 AM	Absent	Absent	0.81 mg/L		JMH 12/12/2022	20221212816
0321	011	Sturgis Physical Therapy (1530 Junction)		12/12/2022 08:00 AM	Absent	Absent	0.94 mg/L		JMH 12/12/2022	20221212817
0321	016	Scott Peterson Motors		12/12/2022 07:45 AM	Absent	Absent	0.75 mg/L		JMH 12/12/2022	20221212818

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

12/14/2022 1:01:38 PM

DATE PRINTED:

12/14/2022 01:25 PM





**MIDCONTINENT**  
TESTING LABORATORIES, INC.

236 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 12/06/22 at 10:45 AM  
by Eric Fuehrer

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	Pete Lien & Sons (2025 Sherman)		12/06/2022 07:30 AM	Absent	Absent	0.74 mg/L		JMH 12/06/2022	20221206822
0321	010	Schneider/Beckwith Dental (1245 Sherman)		12/06/2022 08:15 AM	Absent	Absent	0.47 mg/L		JMH 12/06/2022	20221206823
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		12/06/2022 07:15 AM	Absent	Absent	0.86 mg/L		JMH 12/06/2022	20221206824
0321	020	Liberty Chevrolet		12/06/2022 08:25 AM	Absent	Absent	0.43 mg/L		JMH 12/06/2022	20221206825

REPORT APPROVED BY: Steve Pistan

REPORT APPROVED DATE: 12/7/2022 3:34:40 PM

DATE PRINTED: 12/07/2022 03:50 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

2300 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 11/08/22 at 11:00 AM  
by System Account

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		11/08/2022 09:00 AM	Absent	Absent	0.31 mg/L		JMH 11/08/2022	20221108823
0321	009	Loftus Dental Office (866 Lazelle)		11/08/2022 09:40 AM	Absent	Absent	0.75 mg/L		JMH 11/08/2022	20221108824
0321	014	Ford Regulator (2418 Junction)		11/08/2022 07:00 AM	Absent	Absent	0.75 mg/L		JMH 11/08/2022	20221108825
0321	019	Heritage Acres Building		11/08/2022 07:45 AM	Absent	Absent	0.69 mg/L		JMH 11/08/2022	20221108826

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

11/9/2022 2:38:00 PM

DATE PRINTED:

11/09/2022 02:47 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 10/12/22 at 10:15 AM  
by Eric Fuehrer

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	002	National Guard (701 14th St.)		10/12/2022 08:08 AM	Absent	Absent	0.26 mg/L		JMH 10/12/2022	20221012841
0321	007	Community Center (1401 Lazelle)		10/12/2022 07:00 AM	Absent	Absent	0.74 mg/L		JMH 10/12/2022	20221012842
0321	012	Sturgis Regional Health (2100 Davenport)		10/12/2022 07:30 AM	Absent	Absent	0.64 mg/L		JMH 10/12/2022	20221012843
0321	017	Northern Hills Vet Clinic		10/12/2022 09:19 AM	Absent	Absent	0.46 mg/L		JMH 10/12/2022	20221012844

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

10/13/2022 1:43:17 PM

DATE PRINTED:

10/13/2022 02:03 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 10/03/22 at 10:45 AM  
by System Account

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		10/03/2022 07:20 AM	Absent	Absent	0.64 mg/L		JMH 10/03/2022	20221003805
0321	006	Butte Ridge Building E (1900 Ellen St.)		10/03/2022 07:00 AM	Absent	Absent	0.56 mg/L		JMH 10/03/2022	20221003806
0321	011	Sturgis Physical Therapy (1530 Junction)		10/03/2022 08:28 AM	Absent	Absent	0.66 mg/L		JMH 10/03/2022	20221003807
0321	006	Butte Ridge Building E (1900 Ellen St.)		10/03/2022 08:07 AM	Absent	Absent	0.57 mg/L		JMH 10/03/2022	20221003808

REPORT APPROVED BY:

Steve Disten

REPORT APPROVED DATE:

10/5/2022 10:21:15 AM

DATE PRINTED:

10/05/2022 10:32 AM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 09/20/22 at 10:25 AM  
by Mara Mechaley

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (PIA)	E. COLI SM 9223 B (PIA)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	Pete Lien & Sons (2025 Sherman)		09/20/2022 07:20 AM	Absent	Absent	0.69 mg/L		JMH 09/20/2022	20220920810
0321	010	Schneider/Beckwith Dental (1245 Sherman)		09/20/2022 08:00 AM	Absent	Absent	0.67 mg/L		JMH 09/20/2022	20220920811
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		09/20/2022 06:45 AM	Absent	Absent	0.72 mg/L		JMH 09/20/2022	20220920812
0321	020	Liberty Chevrolet		09/20/2022 07:45 AM	Absent	Absent	0.74 mg/L		JMH 09/20/2022	20220920813

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

9/21/2022 2:21:06 PM

DATE PRINTED:

09/21/2022 02:29 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 09/12/22 at 09:50 AM  
by System Account

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		09/12/2022 07:45 AM	Absent	Absent	0.67 mg/L		JMH 09/12/2022	20220912815
0321	009	Loftus Dental Office (866 Lazelle)		09/12/2022 12:00 AM	Absent	Absent	0.7 mg/L		JMH 09/12/2022	20220912816
0321	014	Ford Regulator (2418 Junction)		09/12/2022 06:45 AM	Absent	Absent	0.71 mg/L		JMH 09/12/2022	20220912817
0321	019	Heritage Acres Building		09/12/2022 07:05 AM	Absent	Absent	0.54 mg/L		JMH 09/12/2022	20220912818

REPORT APPROVED BY:


*Steve Distau*

REPORT APPROVED DATE:

9/13/2022 3:27:23 PM

DATE PRINTED:

09/13/2022 03:36 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 08/16/22 at 10:15 AM  
by Eric Fuehrer

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	003	Speedy Lube (2205 Park Ave)		08/16/2022 08:29 AM	Absent	Absent	0.69 mg/L		JMH 08/16/2022	20220816827
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		08/16/2022 07:10 AM	Absent	Absent	0.46 mg/L		JMH 08/16/2022	20220816828
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		08/16/2022 08:03 AM	Absent	Absent	0.69 mg/L		JMH 08/16/2022	20220816829
0321	018	Little Promises University		08/16/2022 07:48 AM	Absent	Absent	0.67 mg/L		JMH 08/16/2022	20220816830

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

8/17/2022 3:18:40 PM

DATE PRINTED:

08/17/2022 03:33 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 08/01/22 at 11:38 AM  
by Eric Fuehrer

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	002	National Guard (701 14th St.)		08/01/2022 09:50 AM	Absent	Absent	0.31 mg/L		JMH 08/01/2022	20220801821
0321	007	Community Center (1401 Lazelle)		08/01/2022 07:45 AM	Absent	Absent	0.84 mg/L		JMH 08/01/2022	20220801822
0321	012	Sturgis Regional Health (2100 Davenport)		08/01/2022 09:10 AM	Absent	Absent	0.96 mg/L		JMH 08/01/2022	20220801823
0321	017	Northern Hills Vet Clinic		08/01/2022 09:10 AM	Absent	Absent	0.96 mg/L		JMH 08/01/2022	20220801824

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

8/3/2022 8:18:56 AM

DATE PRINTED:

08/03/2022 08:58 AM





**MIDCONTINENT**  
TESTING LABORATORIES, INC.

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 07/12/22 at 11:00 AM  
by System Account

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	011	Sturgis Physical Therapy (1530 Junction)		07/12/2022 09:32 AM	Absent	Absent	0.63 mg/L		JMH 07/12/2022	20220712847
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		07/12/2022 09:41 AM	Absent	Absent	0.82 mg/L		JMH 07/12/2022	20220712848
0321	016	Scott Peterson Motors		07/12/2022 09:53 AM	Absent	Absent	0.79 mg/L		JMH 07/12/2022	20220712849
0321	019	Heritage Acres Building		07/12/2022 10:04 AM	Absent	Absent	1.03 mg/L		JMH 07/12/2022	20220712850

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 7/13/2022 2:27:18 PM

DATE PRINTED: 07/13/2022 02:49 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 07/06/22 at 09:56 AM  
by Dean Aurand

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	Pete Lien & Sons (2025 Sherman)		07/06/2022 07:05 AM	Absent	Absent	0.65 mg/L		JMH 07/06/2022	20220706866
0321	010	Schneider/Beckwith Dental (1245 Sherman)		07/06/2022 08:20 AM	Absent	Absent	0.55 mg/L		JMH 07/06/2022	20220706867
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		07/06/2022 07:15 AM	Absent	Absent	0.68 mg/L		JMH 07/06/2022	20220706868
0321	020	Liberty Chevrolet		07/06/2022 08:50 AM	Absent	Absent	0.53 mg/L		JMH 07/06/2022	20220706869

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

7/7/2022 2:59:51 PM

DATE PRINTED:

07/07/2022 03:31 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 06/15/22 at 09:47 AM  
by Eric Fuehrer

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		06/15/2022 08:06 AM	Absent	Absent	0.62 mg/L		JMH 06/15/2022	20220615828
0321	009	Loftus Dental Office (866 Lazelle)		06/15/2022 08:30 AM	Absent	Absent	0.83 mg/L		JMH 06/15/2022	20220615829
0321	014	Ford Regulator (2418 Junction)		06/15/2022 07:17 AM	Absent	Absent	0.79 mg/L		JMH 06/15/2022	20220615830
0321	019	Heritage Acres Building		06/15/2022 07:49 AM	Absent	Absent	0.93 mg/L		JMH 06/15/2022	20220615831

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 6/16/2022 1:40:46 PM

DATE PRINTED: 06/16/2022 01:43 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 06/06/22 at 08:55 AM  
by Eric Fuehrer

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	003	Speedy Lube (2205 Park Ave)		06/06/2022 07:55 AM	Absent	Absent	0.7 mg/L		JMH 06/06/2022	20220606822
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		06/06/2022 07:40 AM	Absent	Absent	0.55 mg/L		JMH 06/06/2022	20220606823
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		06/06/2022 07:00 AM	Absent	Absent	0.99 mg/L		JMH 06/06/2022	20220606824
0321	018	Little Promises University		06/06/2022 07:20 AM	Absent	Absent	0.81 mg/L		JMH 06/06/2022	20220606825

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

6/8/2022 7:58:43 AM

DATE PRINTED:

06/08/2022 08:47 AM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 05/16/22 at 10:44 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		05/16/2022 09:45 AM	Absent	Absent	0.61 mg/L		JMH 05/16/2022	20220516820
0321	007	Community Center (1401 Lazelle)		05/16/2022 06:40 AM	Absent	Absent	0.83 mg/L		JMH 05/16/2022	20220516821
0321	012	Sturgis Regional Health (2100 Davenport)		05/16/2022 07:25 AM	Absent	Absent	0.89 mg/L		JMH 05/16/2022	20220516822
0321	017	Northern Hills Vet Clinic		05/16/2022 08:30 AM	Absent	Absent	0.83 mg/L		JMH 05/16/2022	20220516823

REPORT APPROVED BY:

*Steve Disten*

REPORT APPROVED DATE:

5/17/2022 3:45:52 PM

DATE PRINTED:

05/17/2022 03:58 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

2221 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 05/09/22 at 01:00 PM  
by System Account

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		05/09/2022 11:00 AM	Absent	Absent	1.01 mg/L		JMH 05/09/2022	20220509821
0321	006	Butte Ridge Building E (1900 Ellen St.)		05/09/2022 11:15 AM	Absent	Absent	0.7 mg/L		JMH 05/09/2022	20220509822
0321	011	Sturgis Physical Therapy (1530 Junction)		05/09/2022 11:00 AM	Absent	Absent	1.02 mg/L		JMH 05/09/2022	20220509823
0321	016	Scott Peterson Motors		05/09/2022 11:30 AM	Absent	Absent	0.9 mg/L		JMH 05/09/2022	20220509824

REPORT APPROVED BY:


*Steve Distau*

REPORT APPROVED DATE:

5/10/2022 2:52:01 PM

DATE PRINTED:

05/10/2022 03:07 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 04/11/22 at 10:00 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	Pete Lien & Sons (2025 Sherman		04/11/2022 08:40 AM	Absent	Absent	1.15 mg/L		JMH 04/11/2022	20220411801
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		04/11/2022 08:07 AM	Absent	Absent	0.85 mg/L		JMH 04/11/2022	20220411802
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		04/11/2022 06:50 AM	Absent	Absent	0.91 mg/L		JMH 04/11/2022	20220411803
0321	018	Little Promises University		04/11/2022 07:35 AM	Absent	Absent	0.82 mg/L		JMH 04/11/2022	20220411804

REPORT APPROVED BY:

*Steve Distas*

REPORT APPROVED DATE:

4/13/2022 9:07:20 AM

DATE PRINTED:

04/13/2022 09:44 AM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

1 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 04/07/22 at 10:30 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	002	National Guard (701 14th St.)		04/07/2022 07:30 AM	Absent	Absent	0.54 mg/L		JMH 04/07/2022	20220407816
0321	007	Community Center (1401 Lazelle)		04/07/2022 06:45 AM	Absent	Absent	0.76 mg/L		JMH 04/07/2022	20220407817
0321	012	Sturgis Regional Health (2100 Davenport)		04/07/2022 08:45 AM	Absent	Absent	1 mg/L		JMH 04/07/2022	20220407818
0321	017	Northern Hills Vet Clinic		04/07/2022 08:10 AM	Absent	Absent	0.88 mg/L		JMH 04/07/2022	20220407819

REPORT APPROVED BY:

*Steve Disten*

REPORT APPROVED DATE:

4/8/2022 2:17:36 PM

DATE PRINTED:

04/08/2022 02:21 PM





**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 03/15/22 at 11:15 AM  
by Eric Fuehrer

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		03/15/2022 08:13 AM	Absent	Absent	1.21 mg/L		JMH 03/15/2022	20220315814
0321	006	Butte Ridge Building E (1900 Ellen St.)		03/15/2022 07:00 AM	Absent	Absent	0.73 mg/L		JMH 03/15/2022	20220315815
0321	011	Sturgis Physical Therapy (1530 Junction)		03/15/2022 08:32 AM	Absent	Absent	1.27 mg/L		JMH 03/15/2022	20220315816
0321	016	Scott Peterson Motors		03/15/2022 07:42 AM	Absent	Absent	0.51 mg/L		JMH 03/15/2022	20220315817

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/17/2022 8:47:49 AM

DATE PRINTED: 03/17/2022 09:13 AM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

331 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 03/09/22 at 09:45 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	005	Pete Lien & Sons (2025 Sherman)		03/09/2022 06:43 AM	Absent	Absent	1.34 mg/L		JMH 03/09/2022	20220309811
0321	010	Schneider/Beckwith Dental (1245 Sherman)		03/09/2022 08:18 AM	Absent	Absent	1.3 mg/L		JMH 03/09/2022	20220309812
0321	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		03/09/2022 07:33 AM	Absent	Absent	1.15 mg/L		JMH 03/09/2022	20220309813
0321	020	Liberty Chevrolet		03/09/2022 07:45 AM	Absent	Absent	0.64 mg/L		JMH 03/09/2022	20220309814

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 3/10/2022 1:46:46 PM

DATE PRINTED: 03/10/2022 01:52 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 02/17/22 at 12:25 PM  
by System Account  
Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	004	Rasmussen Mech. Services (3590 Mayor Ave)		02/17/2022 07:05 AM	Absent	Absent	0.59 mg/L		JMH 02/17/2022	20220217817
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		02/17/2022 07:30 AM	Absent	Absent	0.25 mg/L		JMH 02/17/2022	20220217818
0321	012	Sturgis Regional Health (2100 Davenport)		02/17/2022 09:35 AM	Absent	Absent	0.48 mg/L		JMH 02/17/2022	20220217819
0321	016	Scott Peterson Motors		02/17/2022 09:05 AM	Absent	Absent	0.31 mg/L		JMH 02/17/2022	20220217820

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

2/18/2022 1:28:33 PM

DATE PRINTED:

02/18/2022 01:31 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 02/07/22 at 11:45 AM  
by Steve Ristau

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		02/07/2022 07:32 AM	Absent	Absent	0.73 mg/L		SCR 02/07/2022	20220207809
0321	008	Sturgis City Hall (1040 Harley-Davidson Way)		02/07/2022 08:00 AM	Absent	Absent	0.41 mg/L		SCR 02/07/2022	20220207810
0321	003	Speedy Lube (2205 Park Ave)		02/07/2022 08:30 AM	Absent	Absent	0.65 mg/L		SCR 02/07/2022	20220207811
0321	018	Little Promises University		02/07/2022 08:55 AM	Absent	Absent	0.73 mg/L		SCR 02/07/2022	20220207812

REPORT APPROVED BY:


*Steve Ristau*

REPORT APPROVED DATE:

2/8/2022 2:10:33 PM

DATE PRINTED:

02/08/2022 02:19 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

31 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 01/27/22 at 09:48 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	002	National Guard (701 14th St.)		01/27/2022 07:56 AM	Absent	Absent	0.33 mg/L		JMH 01/27/2022	20220127820
0321	007	Community Center (1401 Lazelle)		01/27/2022 06:48 AM	Absent	Absent	0.35 mg/L		JMH 01/27/2022	20220127821
0321	012	Sturgis Regional Health (2100 Davenport)		01/27/2022 07:36 AM	Absent	Absent	0.89 mg/L		JMH 01/27/2022	20220127822
0321	017	Northern Hills Vet Clinic		01/27/2022 08:21 AM	Absent	Absent	0.95 mg/L		JMH 01/27/2022	20220127823

REPORT APPROVED BY:


*Steve Distau*

REPORT APPROVED DATE:

1/28/2022 2:23:08 PM

DATE PRINTED:

01/28/2022 02:28 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

Purpose: Routine

Received: 01/04/22 at 12:00 PM  
by System Account  
Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
0321	001	G&G Enterprises (2251 Park Ave)		01/04/2022 09:20 AM	Absent	Absent	0.97 mg/L		JMH 01/04/2022	20220104840
0321	006	Butte Ridge Building E (1900 Ellen St.)		01/04/2022 08:00 AM	Absent	Absent	0.86 mg/L		JMH 01/04/2022	20220104841
0321	011	Sturgis Physical Therapy (1530 Junction)		01/04/2022 09:00 AM	Absent	Absent	0.87 mg/L		JMH 01/04/2022	20220104842
0321	016	Scott Peterson Motors		01/04/2022 07:30 AM	Absent	Absent	0.8 mg/L		JMH 01/04/2022	20220104843

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

1/5/2022 3:14:06 PM

DATE PRINTED:

01/05/2022 03:36 PM