



**MIDCONTINENT**  
TESTING LABORATORIES, INC

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1814 DAVENPORT  
Sampled: 06/27/24 at 03:30 AM  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240701913  
Received: 07/01/24 at 09:39 AM  
by Josh Bucknall

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Metals - Total</b>							
Copper (Cu)	0.163	mg/L	10	0.00014	0.005	EPA 200.8	TNA 07/31/24
Lead (Pb)	< 0.0010	mg/L	10	0.000022	0.0010	EPA 200.8	TNA 07/31/24

Approved By: Steve Pistau

Approved On: 8/1/2024 2:12:59 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 105 S AVE  
Sampled: 06/28/24 at 06:05 AM  
Purpose: Routine  
EPA Number: 0321

Sturgis  
Sample Matrix: Water

Lab ID#: 20240701914  
Received: 07/01/24 at 09:39 AM  
by Josh Bucknall  
Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Metals - Total</b>							
Copper (Cu)	0.106	mg/L	10	0.00014	0.005	EPA 200.8	TNA 07/31/24
Lead (Pb)	< 0.0010	mg/L	10	0.000022	0.0010	EPA 200.8	TNA 07/31/24

Approved By: Steve Distau

Approved On: 8/1/2024 2:12:59 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 2002 SUNSET ST  
Sampled: 06/28/24 at 06:00 AM  
Purpose: Routine  
EPA Number: 0321

Sample Matrix: Water Sturgis

Lab ID#: 20240701915  
Received: 07/01/24 at 09:39 AM  
by Josh Bucknall  
Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Metals - Total</b>							
Copper (Cu)	0.097	mg/L	10	0.00014	0.005	EPA 200.8	TNA 07/31/24
Lead (Pb)	< 0.0010	mg/L	10	0.000022	0.0010	EPA 200.8	TNA 07/31/24

Approved By: Steve Distau

Approved On: 8/1/2024 2:12:59 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 810 Shepard St.  
Sampled: 06/27/24 at 07:45 AM  
Purpose: Routine  
EPA Number: 0321

Sturgis  
Sample Matrix: Water

Lab ID#: 20240701916  
Received: 07/01/24 at 09:39 AM  
by Josh Bucknall  
Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Metals - Total</b>							
Copper (Cu)	0.093	mg/L	10	0.00014	0.005	EPA 200.8	TNA 07/31/24
Lead (Pb)	0.0017	mg/L	10	0.000022	0.0010	EPA 200.8	TNA 07/31/24

Approved By: Steve Pistau

Approved On: 8/1/2024 2:12:59 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 1510 JACKSON ST  
Sampled: 06/28/24 at 06:00 AM  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240701917  
Received: 07/01/24 at 09:39 AM  
by Josh Bucknall  
Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Metals - Total</b>							
Copper (Cu)	0.079	mg/L	10	0.00014	0.005	EPA 200.8	TNA 07/31/24
Lead (Pb)	0.0011	mg/L	10	0.000022	0.0010	EPA 200.8	TNA 07/31/24

Approved By: Steve Distau

Approved On: 8/1/2024 2:12:59 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 2120 BALDWIN ST  
Sampled: 06/28/24 at 04:30 AM  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240701918  
Received: 07/01/24 at 09:39 AM  
by Josh Bucknall  
Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Metals - Total</b>							
Copper (Cu)	0.037	mg/L	10	0.00014	0.005	EPA 200.8	TNA 07/31/24
Lead (Pb)	< 0.0010	mg/L	10	0.000022	0.0010	EPA 200.8	TNA 07/31/24

Approved By: Steve Pistau

Approved On: 8/1/2024 2:12:59 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: 973 Howard  
Sampled: 06/27/24 at 12:00 AM  
Purpose: Routine  
EPA Number: 0321

Sturgis  
Sample Matrix: Water

Lab ID#: 20240701919  
Received: 07/01/24 at 09:39 AM  
by Josh Bucknall

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Metals - Total</b>							
Copper (Cu)	0.064	mg/L	10	0.00014	0.005	EPA 200.8	TNA 07/31/24
Lead (Pb)	0.0013	mg/L	10	0.000022	0.0010	EPA 200.8	TNA 07/31/24

Approved By: Steve Pistau

Approved On: 8/1/2024 2:12:59 PM



**DEPARTMENT of AGRICULTURE  
and NATURAL RESOURCES**

JOE FOSS BUILDING  
523 E CAPITOL AVE  
PIERRE SD 57501-3182  
danr.sd.gov

August 07, 2024

Mr. Todd Youngberg  
City of Sturgis  
1057 Dudley St  
Sturgis, SD 57785

SENT VIA EMAIL ONLY TO rbush@sturgisgov.com AND TYoungberg@sturgisgov.com

RE: SOC Sampling for Sturgis (EPA ID 0321)

Dear Mr. Youngberg:

The Drinking Water Program has received the test results of a drinking water compliance sample submitted for analysis of the Synthetic Organic Chemicals (SOC's) from the City of Sturgis for the Treat Site - Well #7 entry point. No regulated SOC's were detected in this sample.

Synthetic Organic Chemicals are divided into seven groups for compliance and waiver purposes. Each of these groups can have a separate sampling requirement depending on your waivers and past sampling history. The SOC sampling status for this entry point is as follows:

*Entry Point: 23 Treat Site - Well #7*

Group	Sampled Last	Current Status	Sampling Requirements
549	05/14/2024	Triennial Monitoring - 50% Complete	A Sample Due In The Third Quarter Of 2024
548	05/14/2024	Triennial Monitoring - 50% Complete	A Sample Due In The Third Quarter Of 2024
547	05/14/2024	Triennial Monitoring - 50% Complete	A Sample Due In The Third Quarter Of 2024
531	05/14/2024	Triennial Monitoring - 50% Complete	A Sample Due In The Third Quarter Of 2024
525	05/14/2024	Triennial Monitoring - 50% Complete	A Sample Due In The Third Quarter Of 2024
515	05/14/2024	Triennial Monitoring - 50% Complete	A Sample Due In The Third Quarter Of 2024
504	05/14/2024	Triennial Monitoring - 50% Complete	A Sample Due In The Third Quarter Of 2024

If you have any questions concerning the test results or SOC monitoring requirements, please call me at 605 773-6576.

Sincerely,

Sammi Blood




 2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
 (605) 348-0111 – www.thechemistrylab.com

 Sample Site: WELL #7  
 Sampled: 05/14/24 at 06:45 AM  
 by Todd Youngberg  
 Purpose: Routine  
 EPA Number: 0321  
 Sturgis  
 Sample Matrix: Water

 RICK BUSH  
 STURGIS WATER COMPANY  
 1040 HARLEY-DAVIDSON WAY  
 STURGIS, SD 57785

 Lab ID#: 20240513617  
 Received: 05/14/24 at 09:30 AM  
 by Jennifer Hill  
 Account: 8392  
 Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
-----------	--------	-------	----	-----	-----	--------	--------------

**SOC Organohalide Pesticides + PCBs**

Alachlor	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Aldrin	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Aroclor 1016	< 0.080	µg/L	1			EPA 525.2	SYS 05/21/24
Aroclor 1221	< 2.00	µg/L	1			EPA 525.2	SYS 05/21/24
Aroclor 1232	< 0.500	µg/L	1			EPA 525.2	SYS 05/21/24
Aroclor 1242	< 0.300	µg/L	1			EPA 525.2	SYS 05/21/24
Aroclor 1248	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Aroclor 1254	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Aroclor 1260	< 0.200	µg/L	1			EPA 525.2	SYS 05/21/24
Chlordane	< 1.00	µg/L	1			EPA 525.2	SYS 05/21/24
Dieldrin	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Endrin	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Heptachlor	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Heptachlor Epoxide	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Hexachlorobenzene	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Hexachlorocyclopentadiene	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Lindane	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Methoxychlor	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Toxaphene	< 2.00	µg/L	1			EPA 525.2	SYS 05/21/24

**SOC Organic Chemicals**

Atrazine	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Benzo (a) pyrene	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Butachlor	< 0.100	µg/L	1			EPA 525.2	SYS 05/31/24
Bis (2-ethylhexyl) Adipate	< 0.500	µg/L	1			EPA 525.2	SYS 05/21/24
Bis (2-ethylhexyl) Phthalate	< 0.600	µg/L	1			EPA 525.2	SYS 05/21/24
Metolachlor	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Metribuzin	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
Propachlor	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>SOC Organic Chemicals</b>							
Simazine	< 0.100	µg/L	1			EPA 525.2	SYS 05/21/24
<b>Semi-Volatile</b>							
DBCP	< 0.050	µg/L	1	0.027	0.050	EPA 504.1	SAC 05/27/24
Ethylene Dibromide(EDB)	< 0.050	µg/L	1	0.034	0.050	EPA 504.1	SAC 05/27/24
<b>SOC Carbamates</b>							
3-Hydroxycarbofuran	< 1.00	µg/L	1			EPA 531.1	SYS 05/17/24
Aldicarb	< 1.00	µg/L	1			EPA 531.1	SYS 05/17/24
Aldicarb Sulfone	< 1.00	µg/L	1			EPA 531.1	SYS 05/17/24
Aldicarb Sulfoxide	< 1.00	µg/L	1			EPA 531.1	SYS 05/17/24
Carbaryl	< 1.00	µg/L	1			EPA 531.1	SYS 05/17/24
Carbofuran	< 1.00	µg/L	1			EPA 531.1	SYS 05/17/24
Methomyl	< 1.00	µg/L	1			EPA 531.1	SYS 05/17/24
Oxamyl	< 1.00	µg/L	1			EPA 531.1	SYS 05/17/24
<b>SOC Diquat</b>							
Diquat Dibromide	< 0.400	µg/L	1			EPA 549.2	SYS 05/23/24
<b>SOC Endothall</b>							
Endothall	< 8.00	µg/L	1			EPA 548.1	SYS 05/31/24
<b>SOC Glyphosate</b>							
Glyphosate	< 50.0	µg/L	1			EPA 547	SYS 05/16/24
<b>SOC Chlorinated Acids</b>							
2,4,5-Trichlorophenoxypropionic acid	< 1.00	µg/L	1			EPA 515.3	SAC 06/06/24
2,4-Dichlorophenoxyacetic acid	< 8.00	µg/L	1			EPA 515.3	SAC 06/06/24
Dalapon	< 10.0	µg/L	1			EPA 515.3	SAC 06/06/24
Dicamba	< 4.00	µg/L	1			EPA 515.3	SAC 06/06/24
Dinoseb	< 1.00	µg/L	1			EPA 515.3	SAC 06/06/24
Pentachlorophenol	< 0.500	µg/L	1			EPA 515.3	SAC 06/06/24
Picloram	< 4.00	µg/L	1			EPA 515.3	SAC 06/06/24

**Notes:**  
 SOC 525, 531, 547, 548, and 549 analysis performed by Energy Laboratories.

Approved By: Steve Distau

Approved On: 7/9/2024 10:29:21 AM



**DEPARTMENT of AGRICULTURE  
and NATURAL RESOURCES**

JOE FOSS BUILDING  
523 E CAPITOL AVE  
PIERRE SD 57501-3182  
danr.sd.gov

June 04, 2024

Mr. Todd Youngberg  
City of Sturgis  
1057 Dudley St  
Sturgis, SD 57785

SENT VIA EMAIL ONLY TO rbush@sturgisgov.com AND TYoungberg@sturgisgov.com

RE: VOC Sampling for Sturgis (EPA ID 0321)

Dear Mr. Youngberg:

The Drinking Water Program has received the test results of a drinking water compliance sample submitted for analysis of the Volatile Organic Chemicals(VOC's) from the City of Sturgis public water supply. The South Dakota Drinking Water Standards require that results of compliance monitoring be kept on file for not less than ten years.

Your system is required to monitor for these contaminants every three years for the entry point, Treat Site - Well #7. No regulated VOC's were detected in this water sample. The next triennial VOC sample for this entry point is due for analysis during 2027. VOC samples are taken at each entry point to the distribution system after treatment.

A summary of your test results is enclosed. If you have any questions concerning the test results or VOC monitoring requirements, please call me at 605 773-6576.

Sincerely,

Sammi Blood  
Drinking Water Program

cy: Rick Bush, Finance Officer

## Regulated Volatile Organic Chemical (VOC) Data

System: City of Sturgis  
 Entry Point: 032123 Treat Site - Well #7  
 Facility: 0321 Sturgis  
 Monitoring Status: Triennially

Definitions: ND - Not Detected  
 ug/l - microgram per liter

Chemical	Date	Value (ug/l)
1,1 Dichloroethylene	05/14/2024	ND
1,1,1 Trichloroethane	05/14/2024	ND
1,1,2-Trichloroethane	05/14/2024	ND
1,2 Dichloroethane	05/14/2024	ND
1,2,4 Trichlorobenzene	05/14/2024	ND
1,2-Dichloropropane	05/14/2024	ND
Benzene	05/14/2024	ND
Carbon Tetrachloride	05/14/2024	ND
Chlorobenzene	05/14/2024	ND
Dichloromethane	05/14/2024	ND
Ethylbenzene	05/14/2024	ND
Styrene	05/14/2024	ND
Tetrachloroethylene	05/14/2024	ND
Toluene	05/14/2024	ND
Trichloroethylene	05/14/2024	ND

Vinyl Chloride	05/14/2024	ND
cis-1,2-Dichloroethylene	05/14/2024	ND
m-Xylene	05/14/2024	ND
o-Dichlorobenzene	05/14/2024	ND
o-Xylene	05/14/2024	ND
p-Xylene	05/14/2024	ND
para-Dichlorobenzene	05/14/2024	ND
trans-1,2-Dichloroethylene	05/14/2024	ND



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: WELL #7  
Sampled: 05/14/24 at 07:08 AM  
by Todd Youngberg  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240514922  
Received: 05/14/24 at 09:30 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	Method	Analyst/Date
<b>Volatile</b>				
Benzene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Carbon Tetrachloride	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Chlorobenzene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
1,2-Dichloroethane	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
1,2-Dichlorobenzene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
1,4-Dichlorobenzene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
1,1-Dichloroethylene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Cis-1,2-Dichloroethylene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Trans-1,2-Dichloroethylene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Dichloromethane	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
1,2-Dichloropropane	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Ethylbenzene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Styrene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Tetrachloroethylene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Toluene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
1,1,1-Trichloroethane	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
1,1,2-Trichloroethane	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
1,2,4-Trichlorobenzene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Trichloroethylene	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Vinyl Chloride	< 0.500	µg/L	EPA 524.2	SYS 05/20/24
Xylenes(o,m,p)	< 0.500	µg/L	EPA 524.2	SYS 05/20/24

Approved By: Steve Distau

Approved On: 5/31/2024 12:22:50 PM



**DEPARTMENT of AGRICULTURE  
and NATURAL RESOURCES**

JOE FOSS BUILDING  
523 E CAPITOL AVE  
PIERRE SD 57501-3182  
danr.sd.gov

May 23, 2024

Mr. Todd Youngberg  
City of Sturgis  
1057 Dudley St  
Sturgis, SD 57785

RE: Sturgis Public Water System (EPA ID 0321)

Dear Mr. Youngberg:

The Drinking Water Program has received the test results of a drinking water compliance sample collected from **Sturgis Public Water System's** entry point on **May 14, 2024**, for the analysis of **nitrate**. The South Dakota Water Standards require that results of compliance monitoring be kept on file for not less than ten years.

The analytical results indicate that the nitrate sample from the entry point is below one-half the maximum contaminant level (MCL) of 10 mg/L. As a result, your system will continue to sample for nitrate on an annual basis. ***The next nitrate sample from your systems entry point will be due for analysis between January 1 and December 31, 2025.***

The nitrate and nitrite samples are "entry point" sampling; samples are to be collected at the entry point to the distribution system just after any treatment that may exist.

If you have questions concerning this letter or the nitrate results, please contact me.

Sincerely,

Peter Mockus  
Drinking Water Program  
(605) 773-4053



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: WELL #7  
Sampled: 05/14/24 at 06:45 AM  
by Todd Youngberg  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240514921  
Received: 05/14/24 at 09:30 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Nitrogen, Nitrate (NO3)	0.454	mg/L	1	0.007	0.050	SM 4500-NO3 F	BLL 05/15/24

Approved By: \_\_\_\_\_

*Steve Pistau*

Approved On: 5/21/2024 9:32:35 AM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: City Waterman (1055 Dudley St.)  
Sampled: 08/13/24 at 09:00 AM  
by Russ Abernatny  
Purpose: Routine  
EPA Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water  
Lab ID#: 20240813852  
Received: 08/13/24 at 09:54 AM  
by Josh Bucknall  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	0.576	mg/L	SM 4500 F-C	IBS 08/14/24
<b>Field Test</b>				
Field Fluoride	0.760	mg/L	Field Fluoride	JMH 08/14/24

Approved By: Steve Distau

Approved On: 8/15/2024 9:57:27 AM



**MIDCONTINENT**  
TESTING LABORATORIES, INC

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)  
Sampled: 07/01/24 at 06:30 AM by Brant Ager  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240701818  
Received: 07/01/24 at 09:38 AM by Josh Bucknall  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	1.12	mg/L	1	0.003	0.010	SM 4500 F-C	IBS 07/02/24
<b>Field Test</b>							
Field Fluoride	1.38	mg/L	1			Field Fluoride	JMH 07/02/24

Approved By: Steve Pistau

Approved On: 7/3/2024 9:36:39 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: **Ford Regulator (2418 Junction)**  
Sampled: 07/09/24 at 07:30 AM  
by Russ Abernatny  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240709882  
Received: 07/09/24 at 09:30 AM  
by System Account  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	1.09	mg/L	1	0.003	0.010	SM 4500 F-C	IBS 07/10/24
<b>Field Test</b>							
Field Fluoride	1.15	mg/L	1			Field Fluoride	SYS 07/10/24

Approved By: Steve Pistau

Approved On: 7/11/2024 9:04:21 AM



**MIDCONTINENT**  
TESTING LABORATORIES, INC

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Community Center (1401  
Lazelle)

Sampled: 06/12/24 at 08:50 AM  
by Russ Abernatny

Purpose: Routine  
EPA  
Number: 0321

Sturgis

Sample  
Matrix: Water

Lab ID#: 20240612930  
Received: 06/12/24 at 10:20 AM  
by Josh Bucknall

Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.792	mg/L	1	0.003	0.010	SM 4500 F-C	IBS 06/13/24
<b>Field Test</b>							
Field Fluoride	0.950	mg/L	1			Field Fluoride	JMH 06/13/24

Approved By: Steve Pistau

Approved On: 6/14/2024 10:44:58 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Butte Ridge Building E  
(1900 Ellen St.)  
Sampled: 06/04/24 at 06:35 AM  
by Brant Ager  
Purpose: Routine  
EPA Number: 0321  
Sample Matrix: Water  
Lab ID#: 20240604948  
Received: 06/04/24 at 10:24 AM  
by Jennifer Hill  
Account: 8392

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sturgis Water Company

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.777	mg/L	1	0.003	0.010	SM 4500 F-C	IBS 06/11/24
<b>Field Test</b>							
Field Fluoride	1.08	mg/L	1			Field Fluoride	JMH 06/05/24

Approved By: Steve Pistau

Approved On: 6/11/2024 3:02:58 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: City Public Works Shop  
(1870 Ballpark Rd)  
Sampled: 05/14/24 at 06:40 AM  
by Russ  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240514812  
Received: 05/14/24 at 11:30 AM  
by System Account  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.673	mg/L	1	0.003	0.010	SM 4500 F-C	IBS 05/16/24
<b>Field Test</b>							
Field Fluoride	1.02	mg/L	1			Field Fluoride	SYS 05/14/24

Approved By: Steve Distau

Approved On: 5/17/2024 9:29:13 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Ford Regulator (2418 Junction)  
Sampled: 05/07/24 at 06:53 AM  
by Brant Ager  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240507873  
Received: 05/07/24 at 09:30 AM  
by Jennifer Hill  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.662	mg/L	1	0.003	0.010	SM 4500 F-C	ELR 05/08/24
<b>Field Test</b>							
Field Fluoride	1.11	mg/L	1			Field Fluoride	JMH 05/08/24

Approved By: Steve Distau

Approved On: 5/8/2024 2:58:09 PM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)  
Sampled: 04/09/24 at 07:10 AM  
by Russ Abernatny  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240409827  
Received: 04/09/24 at 09:45 AM  
by Jennifer Hill  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Non-Metallics</b>							
Fluoride	0.763	mg/L	1	0.003	0.010	SM 4500 F-C	ELR 04/11/24
<b>Field Test</b>							
Field Fluoride	0.940	mg/L	1			Field Fluoride	JMH 04/10/24

Approved By: Steve Piston

Approved On: 4/11/2024 2:18:46 PM





2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Community Center (1401  
Lazelle)  
Sampled: 04/02/24 at 06:35 AM  
by Brant Ager  
Purpose: Routine  
EPA  
Number: 0321  
Sturgis  
Sample  
Matrix: Water  
Lab ID#: 20240402875  
Received: 04/02/24 at 10:10 AM  
by Jennifer Hill  
Account: 8392  
Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
<b>Ion-Metallics</b>							
Fluoride	0.692	mg/L	1	0.003	0.010	SM 4500 F-C	ELR 04/03/24
<b>Field Test</b>							
Field Fluoride	1.00	mg/L	1			Field Fluoride	JMH 04/03/24

Approved By: Steve Pistau

Approved On: 4/4/2024 9:19:38 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Butte Ridge Building E  
(1900 Ellen St.)  
Sampled: 03/12/24 at 08:30 AM  
by R. Abernathy  
Purpose: Routine  
EPA Number: 0321  
Sample Matrix: Water  
Lab ID#: 20240312857  
Received: 03/12/24 at 09:59 AM  
by Jennifer Hill  
Account: 8392

Sturgis

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	0.804	mg/L	SM 4500 F-C	TMN 03/13/24
<b>Field Test</b>				
Field Fluoride	0.980	mg/L	Field Fluoride	SYS 03/12/24

Approved By: Steve Distau

Approved On: 3/14/2024 10:05:21 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: City Waterman (1055 Dudley St.)  
Sampled: 03/06/24 at 08:15 AM  
by Russ Abernatny  
Purpose: Routine  
EPA Number: 0321

Sturgis

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Sample Matrix: Water

Lab ID#: 20240306825  
Received: 03/06/24 at 09:32 AM  
by Jennifer Hill  
Account: 8392

Sturgis Water Company

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	0.697	mg/L	SM 4500 F-C	TMN 03/13/24
<b>Field Test</b>				
Field Fluoride	0.950	mg/L	Field Fluoride	JMH 03/07/24

Approved By: Steve Distau

Approved On: 3/13/2024 10:53:21 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Rasmussen Mech. Services  
(3590 Mayor Ave)  
Sampled: 02/13/24 at 07:15 AM  
by Russ Abernatny  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240213818  
Received: 02/13/24 at 10:00 AM  
by System Account  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	0.914	mg/L	SM 4500 F-C	TMN 02/15/24
<b>Field Test</b>				
Field Fluoride	1.20	mg/L	Field Fluoride	JMH 02/14/24

Approved By: Steve Distau

Approved On: 2/16/2024 9:10:13 AM



**MIDCONTINENT**  
TESTING LABORATORIES, INC

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Water Shop (2901 Vanocker Canyon Rd)  
Sampled: 02/07/24 at 07:15 AM  
by Brant Ager  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240207824  
Received: 02/07/24 at 09:23 AM  
by Sarah Ahlers  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	0.654	mg/L	SM 4500 F-C	TMN 02/12/24
<b>Field Test</b>				
Field Fluoride	1.38	mg/L	Field Fluoride	SYS 02/09/24

Approved By: Steve Pistau

Approved On: 2/12/2024 2:12:34 PM



**MIDCONTINENT**  
TESTING LABORATORIES, INC.

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Community Center (1401  
Lazelle)

Sampled: 01/08/24 at 06:45 AM  
by Russ Abernatny

Purpose: Routine  
EPA  
Number: 0321

Sturgis

Sample  
Matrix: Water

Lab ID#: 20240108838  
Received: 01/08/24 at 10:00 AM  
by System Account  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	0.752	mg/L	SM 4500 F-C	TMN 01/15/24
<b>Field Test</b>				
Field Fluoride	0.940	mg/L	Field Fluoride	JMH 01/09/24

Approved By: Steve Pistau

Approved On: 1/15/2024 11:27:35 AM



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 – www.thechemistrylab.com

Sample Site: Sturgis Parks Dept. Shop  
(1920 Ballpark A)  
Sampled: 01/02/24 at 08:30 AM  
by Brant Ager  
Purpose: Routine  
EPA Number: 0321

Sturgis

Sample Matrix: Water

Lab ID#: 20240102827  
Received: 01/02/24 at 10:30 AM  
by Jennifer Hill  
Account: 8392

Sturgis Water Company

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

Parameter	Result	Units	Method	Analyst/Date
<b>Non-Metallics</b>				
Fluoride	0.745	mg/L	SM 4500 F-C	TMN 01/04/24
<b>Field Test</b>				
Field Fluoride	1.02	mg/L	Field Fluoride	JMH 01/03/24

Approved By: Steve Pistau

Approved On: 1/4/2024 2:59:04 PM



Purpose: Routine

Received: 08/13/24 at 09:54 AM  
by Josh Bucknall

Account: 8392  
Sturgis Water Company

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	005	City Waterman (1055 Dudley St.)		08/13/2024 09:00 AM	Present	Absent	0.67 mg/L		SAA 08/13/2024	20240813812
21	010	Schneider/Beckwith Dental (1245 Sherman)		08/13/2024 08:15 AM	Absent	Absent	0.67 mg/L		SAA 08/13/2024	20240813813
21	015	City Public Works Shop (1870 Ballpark Rd)		08/13/2024 08:30 AM	Absent	Absent	0.67 mg/L		SAA 08/13/2024	20240813814
21	020	Liberty Chevrolet		08/13/2024 08:00 AM	Absent	Absent	0.51 mg/L		SAA 08/13/2024	20240813815

REPORT APPROVED BY:

Steve Distau

REPORT APPROVED DATE:

8/14/2024 2:39:00 PM

DATE PRINTED:

08/14/2024 02:58 PM





Purpose: Routine

Received: 07/09/24 at 09:30 AM  
by System Account

Account: 8392  
Sturgis Water Company

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

:PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	004	Rasmussen Mech. Services (3590 Mayor Ave)		07/09/2024 06:35 AM	Absent	Absent	0.55 mg/L		SAA 07/09/2024	20240709831
21	009	Loftus Dental Office (866 Lazelle)		07/09/2024 08:40 AM	Absent	Absent	0.81 mg/L		SAA 07/09/2024	20240709832
21	014	Ford Regulator (2418 Junction)		07/09/2024 07:30 AM	Absent	Absent	1.09 mg/L		SAA 07/09/2024	20240709833
21	019	Heritage Acres Bldg #2		07/09/2024 08:00 AM	Absent	Absent	0.89 mg/L		SAA 07/09/2024	20240709834

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 7/10/2024 3:26:29 PM

DATE PRINTED: 07/10/2024 03:34 PM



Purpose: Routine

Received: 07/01/24 at 09:38 AM  
by Josh Bucknall

Account: 8392  
Sturgis Water Company

381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	003	Speedy Lube (2205 Park Ave)		07/01/2024 08:35 AM	Absent	Absent	1.13 mg/L		JMH 07/01/2024	20240701813
21	008	Sturgis City Hall (1040 Harley-Davidson Way)		07/01/2024 08:20 AM	Absent	Absent	0.6 mg/L		JMH 07/01/2024	20240701814
21	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		07/01/2024 06:25 AM	Absent	Absent	1.31 mg/L		JMH 07/01/2024	20240701815
21	018	Little Promises University		07/01/2024 08:00 AM	Absent	Absent	1.22 mg/L		JMH 07/01/2024	20240701816

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

7/3/2024 9:36:39 AM

DATE PRINTED:

07/03/2024 09:56 AM



Purpose: Routine

Received: 06/12/24 at 10:20 AM  
by Josh Bucknall

Account: 8392  
Sturgis Water Company

381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
11	001	G&G Enterprises (2251 Park Ave)		06/12/2024 07:15 AM	Absent	Absent	0.78 mg/L		JMH 06/12/2024	20240612813
11	007	Community Center (1401 Lazelle)		06/12/2024 08:50 AM	Absent	Absent	0.46 mg/L		JMH 06/12/2024	20240612814
11	012	Sturgis Regional Health (2100 Davenport)		06/12/2024 08:30 AM	Absent	Absent	0.49 mg/L		JMH 06/12/2024	20240612815
11	017	Northern Hills Vet Clinic		06/12/2024 08:10 AM	Absent	Absent	0.79 mg/L		JMH 06/12/2024	20240612816

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

6/13/2024 2:10:52 PM

DATE PRINTED:

06/13/2024 02:54 PM



Purpose: Routine

Received: 06/04/24 at 10:24 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

:PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	002	National Guard (701 14th St.)		06/04/2024 07:12 AM	Absent	Absent	0.34 mg/L		JMH 06/04/2024	20240604861
21	006	Butte Ridge Building E (1900 Ellen St.)		06/04/2024 06:35 AM	Absent	Absent	0.56 mg/L		JMH 06/04/2024	20240604862
21	011	Sturgis Physical Therapy (1530 Junction)		06/04/2024 08:10 AM	Absent	Absent	0.49 mg/L		JMH 06/04/2024	20240604863
21	016	Scott Peterson Motors		06/04/2024 07:31 AM	Absent	Absent	0.93 mg/L		JMH 06/04/2024	20240604864

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

6/5/2024 2:43:00 PM

DATE PRINTED:

06/05/2024 03:05 PM



Purpose: Routine

Received: 05/14/24 at 12:00 PM  
by System Account

Account: 8392  
Sturgis Water Company

1381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	005	City Waterman (1055 Dudley St.)		05/14/2024 07:30 AM	Absent	Absent	0.95 mg/L		JMH 05/14/2024	20240514826
21	008	Sturgis City Hall (1040 Harley-Davidson Way)		05/14/2024 07:40 AM	Absent	Absent	0.7 mg/L		JMH 05/14/2024	20240514827
21	015	City Public Works Shop (1870 Ballpark Rd)		05/14/2024 06:40 AM	Absent	Absent	0.77 mg/L		JMH 05/14/2024	20240514828
21	020	Liberty Chevrolet		05/14/2024 07:10 AM	Absent	Absent	0.84 mg/L		JMH 05/14/2024	20240514829

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

5/15/2024 2:23:52 PM

DATE PRINTED:

05/15/2024 02:30 PM



Purpose: Routine

Received: 05/14/24 at 12:00 PM  
by System Account

Account: 8392  
Sturgis Water Company

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

EPA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	005	City Waterman (1055 Dudley St.)		05/14/2024 07:30 AM	Absent	Absent	0.95 mg/L		JMH 05/14/2024	20240514826
21	008	Sturgis City Hall (1040 Harley-Davidson Way)		05/14/2024 07:40 AM	Absent	Absent	0.7 mg/L		JMH 05/14/2024	20240514827
21	015	City Public Works Shop (1870 Ballpark Rd)		05/14/2024 06:40 AM	Absent	Absent	0.77 mg/L		JMH 05/14/2024	20240514828
21	020	Liberty Chevrolet		05/14/2024 07:10 AM	Absent	Absent	0.84 mg/L		JMH 05/14/2024	20240514829

REPORT APPROVED BY:

*Steve Distau*

REPORT APPROVED DATE:

5/15/2024 2:23:52 PM

DATE PRINTED:

05/15/2024 02:30 PM



Purpose: Routine

Received: 05/07/24 at 09:30 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

1381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	004	Rasmussen Mech. Services (3590 Mayor Ave)		05/07/2024 08:11 AM	Absent	Absent	0.5 mg/L		JMH 05/07/2024	20240507822
21	009	Loftus Dental Office (866 Lazelle)		05/07/2024 07:55 AM	Absent	Absent	0.73 mg/L		JMH 05/07/2024	20240507823
21	014	Ford Regulator (2418 Junction)		05/07/2024 06:55 AM	Absent	Absent	0.65 mg/L		JMH 05/07/2024	20240507824
21	019	Heritage Acres Bldg #2		05/07/2024 07:07 AM	Absent	Absent	0.63 mg/L		JMH 05/07/2024	20240507825

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 5/8/2024 2:58:09 PM

DATE PRINTED: 05/08/2024 03:11 PM



Purpose: Routine

Received: 04/09/24 at 09:45 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	003	Speedy Lube (2205 Park Ave)		04/09/2024 08:30 AM	Absent	Absent	0.76 mg/L		JMH 04/09/2024	20240409807
21	008	Sturgis City Hall (1040 Harley-Davidson Way)		04/09/2024 07:45 AM	Absent	Absent	0.74 mg/L		JMH 04/09/2024	20240409808
21	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		04/09/2024 07:10 AM	Absent	Absent	0.97 mg/L		JMH 04/09/2024	20240409809
21	018	Little Promises University		04/09/2024 12:00 AM	Absent	Absent	0.89 mg/L		JMH 04/09/2024	20240409810

REPORT APPROVED BY: Steve Pistau

REPORT APPROVED DATE: 4/10/2024 2:35:45 PM

DATE PRINTED: 04/10/2024 03:38 PM





Purpose: Routine

Received: 04/02/24 at 10:10 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
1	002	National Guard (701 14th St.)		04/02/2024 06:50 AM	Absent	Absent	0.57 mg/L		JMH 04/02/2024	20240402829
1	007	Community Center (1401 Lazelle)		04/02/2024 06:30 AM	Absent	Absent	0.83 mg/L		JMH 04/02/2024	20240402830
1	012	Sturgis Regional Health (2100 Davenport)		04/02/2024 07:11 AM	Absent	Absent	0.72 mg/L		JMH 04/02/2024	20240402831
1	017	Northern Hills Vet Clinic		04/02/2024 08:10 AM	Absent	Absent	0.81 mg/L		JMH 04/02/2024	20240402832

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 4/3/2024 2:53:40 PM

DATE PRINTED: 04/03/2024 03:10 PM



Purpose: Routine

Received: 03/06/24 at 09:32 AM  
by Jennifer Hill

Account: 8392  
Sturgis Water Company

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

:PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	005	City Waterman (1055 Dudley St.)		03/06/2024 08:15 AM	Absent	Absent	0.79 mg/L		JMH 03/06/2024	20240306814
21	010	Schneider/Beckwith Dental (1245 Sherman)		03/06/2024 08:00 AM	Absent	Absent	0.47 mg/L		JMH 03/06/2024	20240306815
21	015	City Public Works Shop (1870 Ballpark Rd)		03/06/2024 07:30 AM	Absent	Absent	0.61 mg/L		JMH 03/06/2024	20240306816
21	020	Liberty Chevrolet		03/06/2024 07:50 AM	Absent	Absent	0.59 mg/L		JMH 03/06/2024	20240306817

REPORT APPROVED BY:

*Steve Disten*

REPORT APPROVED DATE:

3/8/2024 10:50:48 AM

DATE PRINTED:

03/08/2024 10:59 AM



Purpose: Routine

Received: 02/13/24 at 10:00 AM  
by System Account

Account: 8392  
Sturgis Water Company

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

:PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	004	Rasmussen Mech. Services (3590 Mayor Ave)		02/13/2024 07:15 AM	Absent	Absent	0.71 mg/L		JMH 02/13/2024	20240213814
21	009	Loftus Dental Office (866 Lazelle)		02/13/2024 08:00 AM	Absent	Absent	0.64 mg/L		JMH 02/13/2024	20240213815
21	014	Ford Regulator (2418 Junction)		02/13/2024 06:30 AM	Absent	Absent	0.77 mg/L		JMH 02/13/2024	20240213816
21	019	Heritage Acres Bldg #2		02/13/2024 07:00 AM	Absent	Absent	0.68 mg/L		JMH 02/13/2024	20240213817

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 2/14/2024 2:23:15 PM

DATE PRINTED: 02/14/2024 02:40 PM



Purpose: Routine

Received: 02/07/24 at 09:23 AM  
by Sarah Ahlers

Account: 8392  
Sturgis Water Company

381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	002	National Guard (701 14th St.)		02/07/2024 08:15 AM	Absent	Absent	0.71 mg/L		JMH 02/07/2024	20240207805
21	008	Sturgis City Hall (1040 Harley-Davidson Way)		02/07/2024 07:50 AM	Absent	Absent	0.62 mg/L		JMH 02/07/2024	20240207806
21	013	Sturgis Water Shop (2901 Vanocker Canyon Rd)		02/07/2024 07:15 AM	Absent	Absent	0.85 mg/L		JMH 02/07/2024	20240207807
21	018	Little Promises University		02/07/2024 07:30 AM	Absent	Absent	0.91 mg/L		JMH 02/07/2024	20240207808

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 2/8/2024 2:40:56 PM

DATE PRINTED: 02/08/2024 02:49 PM



Purpose: Routine

Received: 01/08/24 at 10:00 AM  
by System Account

Account: 8392  
Sturgis Water Company

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

:PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	003	Speedy Lube (2205 Park Ave)		01/08/2024 08:30 AM	Absent	Absent	0.68 mg/L		SAA 01/08/2024	20240108811
21	007	Community Center (1401 Lazelle)		01/08/2024 06:45 AM	Absent	Absent	0.6 mg/L		SAA 01/08/2024	20240108812
21	012	Sturgis Regional Health (2100 Davenport)		01/08/2024 06:45 AM	Absent	Absent	0.46 mg/L		SAA 01/08/2024	20240108813
21	017	Northern Hills Vet Clinic		01/08/2024 08:00 AM	Absent	Absent	0.85 mg/L		SAA 01/08/2024	20240108814

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 1/9/2024 3:32:51 PM

DATE PRINTED: 01/09/2024 03:40 PM



Purpose: Routine

Received: 01/02/24 at 10:15 AM  
by System Account

Account: 8392  
Sturgis Water Company

2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709  
(605) 348-0111 -- www.thechemistrylab.com

RICK BUSH  
STURGIS WATER COMPANY  
1040 HARLEY-DAVIDSON WAY  
STURGIS, SD 57785

**MUNICIPAL DRINKING WATER REPORT**

:PA #	SITE #	SAMPLE SITE	SAMPLE POINT	SAMPLE DATE & TIME	TOTAL COLIFORM SM 9223 B (P/A)	E. COLI SM 9223 B (P/A)	FIELD TESTS		ANALYST	LAB NUMBER
							RESIDUAL CL	PH		
21	006	Butte Ridge Building E (1900 Ellen St.)		01/02/2024 07:21 AM	Absent	Absent	0.36 mg/L		JMH 01/02/2024	20240102819
21	007	Community Center (1401 Lazelle)		01/02/2024 09:05 AM	Absent	Absent	0.81 mg/L		JMH 01/02/2024	20240102820
21	015	Sturgis Parks Dept. Shop (1920 Ballpark A)		01/02/2024 08:30 AM	Absent	Absent	0.63 mg/L		JMH 01/02/2024	20240102821
21	019	Heritage Acres Building		01/02/2024 08:50 AM	Absent	Absent	0.73 mg/L		JMH 01/02/2024	20240102822

REPORT APPROVED BY: Steve Distau

REPORT APPROVED DATE: 1/4/2024 7:51:25 AM

DATE PRINTED: 01/04/2024 08:17 AM